Q. **Reference: Additions to Accommodate Load Growth – Hopedale, Volume II, Report 25, Page 13, Table 10**

Please provide a table showing the forecasted and actual net peak loads for 2008 to 2012.

A. Please see the table below that provides the actual and forecasted net peak loads for Hopedale on a winter peak basis. Between the fall of 2010 and the spring of 2012, Hydro changed its forecasting schedule from the fall of the year to the spring of the year.

Hopedale Actual and Forecast Net Peak (kW)

Year	Actual	Forecasts				
		Fall 2007	Fall 2008	Fall 2009	Fall 2010	Spring 2012
2008	803	787				
2009	858	829	795			
2010	896	846	830	863		
2011	834	865	850	895	842	
2012	924	881	867	923	872	881
Note: Net peaks are forecast and presented on a winter peak basis.						