

1 Q. Volume I, Tab Holyrood Overview, page 6: Hydro states that: *"During the*
2 *standby phase, it is assumed that the plant will produce 20 GWh in each year to*
3 *test the units to ensure that they are available if required."*

4 Has Hydro developed a plan with regard to how the Holyrood plant will be operated
5 during the standby years? If so, please provide a copy, ensuring that it addresses
6 the seasonal nature of the standby and whether it will be a cold or a hot standby.

7
8
9 A. Hydro has not yet developed a specific plan with regard to how the Holyrood Plant
10 will be operated during the standby years. The annual energy production indicated
11 for the standby phase assumes an equivalent of one week operation per unit, per
12 year, five days at 100 MW and two days at full load. A specific plan, once
13 developed, will consider the seasonal nature of the standby and determine
14 requirements (hot or cold) to ensure that the system continues to be operated in a
15 reliable and secure manner.