

1 Q. E-5; Volume I, Tab E: Install Automated Fuel Monitoring System at West Salmon  
2 Spillway – Bay D’Espoir, page E-8:

3 In Order No. P.U. 4(2013) the Board ordered that the: *“Automated Fuel Monitoring*  
4 *System, Upper Salmon (\$192,700) is approved but costs for this project will not be*  
5 *recovered unless otherwise ordered by the Board.”* What is the status of the  
6 required verification that a variance from the legislative requirement for weekly  
7 tank dipping has been obtained by Hydro in order that the Board may deal with this  
8 matter?

9  
10

11 A. The “Automated Fuel Monitoring System, Upper Salmon” project is currently  
12 underway with a scheduled installation date of November 2013. Hydro is confident  
13 that a variance will be granted when the system is in service based on previous  
14 communications with the regulating body, and the fact that a system with the same  
15 functionality in Cat Arm was previously granted a variance to the same regulation.