

1 **Q. E-66; Volume I, Tab E: Replace DC Distribution Panels and Breakers – Holyrood:**

2 Since the replacement of the DC Distribution Panels and Breakers at Holyrood was
3 not included in the Five-Year Plan included in the 2013 Capital Budget Application,
4 please provide justification for the inclusion of this project in the 2014 Capital
5 Budget.

6

7

8 **A.** This project was included in the five-year capital plan under the title “Upgrade
9 129VDC Plant Wide Distribution System - Holyrood”. Due to panel configurations
10 and locations, it was decided to replace DC panels and breakers (129VDC and
11 258VDC) on Units 1 and 2 in 2014. The project “Replace 258VDC Distribution Panels
12 and Breakers-Holyrood” in 2015 will now replace DC panels and breakers (129VDC
13 and 258VDC) on Unit 3.