

1 Q. How many generating units at Muskrat Falls are required to equal the total output
2 of Holyrood?

3

4

5 A. The Holyrood Thermal Generating Station consists of three units having a combined
6 net capacity of 465.5 MW (i.e., output to the system). By comparison, the Muskrat
7 Falls hydro-electric generating station will consist of four 206 MW units for a total
8 plant capacity of 824 MW. In simple terms, ignoring transmission system losses, a
9 minimum of three Muskrat Falls generators are required to provide the 465.5 MW
10 of capacity from Holyrood.