

1 Q. **Holyrood – Overhaul Turbine/Generator Unit 2 - \$5,147,000**

2 Section 3 on page 7 of the Report to the PUB entitled “*Overhaul Steam Turbine*  
3 *Generator – Unit 2, Holyrood, June 2013*” states that “*Holyrood supplies*  
4 *approximately 33 percent of the Island Interconnected System’s capacity .....*”.

5 Please show the calculation used to determine this percentage.  
6  
7

8 A. This calculation refers to Hydro’s Island Interconnected System, which has a  
9 capacity of approximately 1,500 MW. The Holyrood Thermal Generating Plant  
10 provides 465.5 MW net, which is approximately 1/3 or 33%.

11  
12 The total Island Interconnected System, including Hydro, customer generation and  
13 non-utility generators, has a capacity of approximately 1,950 MW. Holyrood  
14 provides approximately 24% of the total Island Interconnected System’s capacity.