

1 Q. **Project: Holyrood - Complete Condition Assessment Phase 2 – \$1,476,000**

2 Reference: Report to the PUB, *“Condition Assessment and Life Extension, Holyrood,*
3 *June 2013”*

4 a) In the report summary it states that *“This project is the third year of a level 2*
5 *condition assessment study of the Holyrood Thermal Generating Station”*.

6 The previous two years were prior to the approval of the Muskrat Falls
7 Generation project. Now, with Muskrat Falls fully approved and scheduled to
8 be at full production by mid-2017, please explain the rationale for completing
9 the condition assessment.

10 b) Page 3 of the Report states *“However, Unit 2’s generator inspection will take*
11 *place under this project”*. Please confirm that the cost for the generator
12 inspection is not also included in the project to overhaul Turbine/Generator
13 Unit 2.

14
15
16 A. a) The scope of the condition assessment work being proposed for 2014 was
17 prepared with consideration to the future operating schedule of the plant
18 resulting from approval of the Muskrat Falls Generation project. The results of
19 this project, as in the case of the results from the first and second years of Level
20 2 assessment, will provide recommendations with cost estimates to perform
21 refurbishments that may be necessary to select systems to ensure safety and
22 reliability of the plant as it continues to operate in generation mode to the year
23 2017, synchronous condensing with standby generation from 2017 to 2020, and
24 in synchronous condensing mode thereafter.

25
26 b) It is confirmed that the cost of Unit 2 generator inspection is not also included in
27 the project to overhaul Turbine/Generator Unit 2.