

1 Q. **Evidence – Application for Deferral and Recovery of 2014 Capacity-Related Supply**
2 **Costs, Page 2, Table 1.**

3 Please provide a table that shows which of Hydro's plants were available but not in
4 operation for each time that CBPP was providing capacity assistance.

5

6

7 A. There was one instance when Hydro's plants were available but not in operation
8 when CBPP was providing capacity assistance.

9

10 On January 6, 2014, for the capacity assistance request made at 20:00 hours, the St.
11 Anthony Diesel plant (9.7 MW Capacity) and Hawke's Bay Diesel plant (5.0 MW
12 Capacity) were available but not in operation.

13

14 Hydro notes that the capacity assistance requested during this period was for 40
15 MW, i.e., substantially greater than the combined capacity of the St. Anthony and
16 the Hawke's Bay plants. As such, if these plants were operated, the capacity
17 assistance would still have to be requested.