

1 Q. **Evidence - Application for Deferral and Recovery of 2014 Capacity-Related Supply**
2 **Costs, page 7, lines 9-15.**

3 Please provide a list of applications Hydro intends to file for the remainder of 2014.
4
5

6 A. For the remainder of 2014, Hydro intends to file the following applications: an
7 Amended General Rate application (filed November 10, 2014); a supplemental
8 application for critical spares (filed November 4, 2014); an application for approval
9 of interruptible/capacity assistance agreement(s) (the first of which was filed
10 October 28, 2014); and application(s) to address cost recovery of capital
11 expenditures not yet approved for inclusion in rate base. The Amended General
12 Rate Application will also request approval of interim rates early in 2015.
13

14 A recent failure of a power transformer (Corner Brook Frequency Converter T2
15 which is installed solely for Corner Brook Pulp and Paper) may require an
16 application for the replacement, rewind, or repair of the transformer. Following a
17 fault and subsequent internal inspection of the transformer, an on-site assessment
18 determined that a repair of the transformer requires being in a transformer shop,
19 and therefore cannot be performed on site. Hydro is awaiting details on the cost of
20 each of the following three options: repairing the transformer; rewinding the
21 transformer; and replacing the transformer. Once detailed estimates for these
22 options are received, Hydro will review and determine the most appropriate course
23 of action, and if an application to the Board is necessary. Hydro is utilizing a power
24 transformer owned by Corner Brook Pulp and Paper while T2 is out of service.