

1 Q. Re: Page B-20: Provide details of the occurrences of failed batteries in the  
2 past five (5) years and indicate the effect on the grid of each of these failures.

3

4

5 A. At the Holyrood plant there are four UPS systems. UPS # 1,2 & 3 are for  
6 each generating unit and UPS # 4 is for common station services. These  
7 UPS's provide critical AC station services for the generating units.

8

9 The following is the list of failed battery replacements that have occurred  
10 over the last 5 years:

11 UPS # 3 – Replaced one failed cell – May 24, 2005

12 UPS # 4 - Replaced two failed cells - May 24, 2005

13 UPS # 1 – Replaced three failed cells – May 24, 2005

14 UPS # 1 – Replaced battery bank – September 15, 2004

15 UPS # 2 – Replaced battery bank – September 23, 2004

16 UPS # 2 – Replaced three failed cells – June 16, 2003.

17 UPS # 1 – Replaced three failed cells – May 2, 2002

18

19 The failures on UPS # 1, 2 & 3 were detected during the regular PM  
20 inspections and the replacements were made before the failure could cause  
21 a generating unit outage.

22

23 The failure on UPS # 4 was not detected during the regular inspections. The  
24 failure caused an interruption to the station service controls systems which  
25 resulted in power outages to some areas of the plant, but fortunately there  
26 were no generating unit outages.

1 If the battery were to fail on UPS 1, 2 or 3 and was not detected then it could  
2 result in a unit outage and a loss of up to 170 MW to the system. A loss of  
3 this magnitude would initiate the under-frequency load-shedding scheme,  
4 which would interrupt the energy supply to major portions of the provincial  
5 system.

6  
7 The battery monitoring system proposed would continuously monitor the  
8 batteries in all four UPS's and initiate an alarm should a battery or battery cell  
9 failure occur. This advance warning would ensure corrective action could be  
10 taken and generating unit outages would be prevented.