

1 Q. With respect to Project B-22, Upgrade Unit 3 Air Preheater Steam  
2 Condensate System, how was the fuel system estimate of \$160,000 per year  
3 arrived at? What fuel savings per year have been measurably achieved by  
4 the similar modifications of Units 1 and 2?

5

6

7 A. It has been necessary to operate Unit 3 boiler with its combustion air heater  
8 operating at higher steam pressure than normal, to evacuate all the  
9 condensate from the air heaters. This higher steam pressure raises the  
10 average cold end temperature (ACET) higher than optimal (in essence, this  
11 means that the temperature of the exhaust gas exiting the stack is higher  
12 than it otherwise needs to be, consuming more fuel). The installation of a  
13 condensate pumping system will enable a reduction of steam pressure,  
14 thereby lowering ACET and reducing fuel consumption. This reduction in fuel  
15 consumption will result in a saving of \$160,00.00 per year.

16

17 Fuel savings resulting from similar modifications to Units 1 and 2 have not  
18 been measured, however, it is possible to operate these units at the lower  
19 ACET without incurring piping system damage.