

1 Q. In the same way that NLH references the condition of the Hardwoods plant to
2 assess the condition of the Stephenville fuel pipes, could a condition
3 assessment of one unit at Holyrood serve to inform as to the condition of the
4 other units, especially in relation to units 1 and 2?

5

6

7 A. It is possible to make some inferences between units concerning the
8 condition of some auxiliary equipment and such relationships will be used to
9 determine the level of assessment required for these components. It is
10 dangerous to make such inferences about major equipment, such as boilers
11 and turbines, which are subjected to similar but different operating
12 conditions, water quality, corrosion rates and other variables.