

1 Q. Can the Holyrood DAFOR data be segregated for each generation unit? If  
2 not, can it be determined from other information sources if the DAFOR  
3 information is subject to a disproportionate number of equipment failures  
4 related to a single generation unit?

5  
6  
7  
8

A. The following provides DAFOR (in %) by unit at Holyrood.

| Year | Unit 1                  | Unit 2 | Unit 3 |
|------|-------------------------|--------|--------|
| 1979 | 47.34                   | 4.64   |        |
| 1980 | 14.47                   | 19.50  | 53.08  |
| 1981 | 29.65                   | 22.72  | 14.62  |
| 1982 | 18.11                   | 18.98  | 9.64   |
| 1983 | <i>Data Unavailable</i> |        |        |
| 1984 | 8.93                    | 1.73   | 21.98  |
| 1985 | 19.29                   | 1.46   | 1.10   |
| 1986 | 9.78                    | 29.50  | 32.93  |
| 1987 | 14.33                   | 3.06   | 14.19  |
| 1988 | 17.58                   | 11.99  | 9.10   |
| 1989 | 12.66                   | 26.35  | 16.2   |
| 1990 | 17.90                   | 30.99  | 19.27  |
| 1991 | 18.69                   | 39.34  | 41.26  |
| 1992 | 9.34                    | 46.47  | 27.16  |
| 1993 | 14.30                   | 29.36  | 40.77  |
| 1994 | 4.53                    | 16.48  | 28.98  |
| 1995 | 4.79                    | 33.64  | 21.16  |
| 1996 | 9.68                    | 13.07  | 23.92  |
| 1997 | 10.14                   | 5.19   | 11.30  |
| 1998 | 6.04                    | 4.53   | 2.65   |
| 1999 | 3.16                    | 22.61  | 4.81   |
| 2000 | 3.30                    | 3.63   | 1.29   |
| 2001 | 5.48                    | 3.34   | 2.55   |
| 2002 | 6.37                    | 5.70   | 23.25  |
| 2003 | 14.56                   | 3.22   | 3.67   |
| 2004 | 4.12                    | 13.27  | 4.21   |
| 2005 | 0.61                    | 9.18   | 11.8   |

9