

1    **B-16 Upgrade Unit NO. 3 Turbine/Generator, \$1,654,300**

2    Q.    Has the maintenance schedule of the units at Holyrood been affected by the  
3           decrease in load caused by the closure of Abitibi in Stephenville and by the  
4           capacity added to the system by NUGS?

5

6

7    A.    There has not been any change in the maintenance schedule as a result of  
8           these two issues. The effect of these two events has been a reduction in the  
9           average output of the Holyrood units, but the reduction in operating hours will  
10          not be sufficient to modify the maintenance schedule.