

1 **B-16 Upgrade Unit NO. 3 Turbine/Generator, \$1,654,300**

2 Q. Is the planned change in the maintenance schedule at Holyrood related in
3 any way to the proposed Holyrood Condition Assessment?

4

5

6 A. No. The maintenance schedule is designed to ensure that the plant achieves
7 its original design life, while the condition assessment will determine how
8 long it is possible to economically extend that life.