

B-7 Upgrade Cooling Water System Units No's 1 and 2, \$112,200

Q. Provide a listing of instances of fouled or leaking piping that have required remedial attention during the years 2004 to 2006F.

A. There were no fouling or leak events on Units 1 and 2 during the period 2004 to June 2006. There have been such incidents in previous years on these and other units in the Bay D'Espoir plant. Inspections performed on the piping systems have revealed extensive fouling and corrosion. It is prudent to replace this piping before a failure can occur during the peak generating season, which could cause an interruption of supply to customers.

Attached are copies of the two most recent preventive maintenance inspections for the surface air coolers on each unit. The surface air cooler leak inspections are visual and reporting is done in a non-formal way by means of verbal communication.

The preventive maintenance inspection reports show that the surface air cooler flow rates for both the North and South headers are below the normal required flow rate that is specified at 1100 lpm.

Corrosion of the surface air cooler piping is the major concern on these systems. The surface air cooler piping system is designed to use a Victaulic coupling system for ease of removal, installation, and inspection of the piping. The condition of the pipe ends and fittings is critical when using a Victaulic coupling system to ensure a good seal.

1 The corrosion within the 4-inch schedule 40 surface air cooler piping is
2 approximately 0.080 – 0.110 inches deep. The 4-inch schedule 40 pipe has
3 a wall thickness of 0.237-inch with Victaulic end cut grooves that are
4 between 0.080 – 0.100 inches deep. The minimum pipe wall thickness in
5 these Victaulic end cut grooves is 0.137-inch when the pipe was new. Given
6 a maximum corrosion depth of 0.110-inch inside the pipe leaves only 0.027-
7 inch pipe wall at the Victaulic end cut groove. In addition, there is extensive
8 pipe end corrosion that makes it difficult to ensure a leak free seal. Each unit
9 has approximately 120 cut groove Victaulic end connections on the surface
10 air-cooling water system.

11
12 The average fouling thickness is measured to be around 1/4-inch, this can be
13 seen in picture 4 on a section of 2-inch schedule 40 pipe. This amount of
14 fouling reduces the flow rate through this pipe by approximately 45%.

15
16 Below are pictures of the pipe that show the typical state of corrosion that
17 can be found through out this 40 year old cooling water system.



Picture 1

A fouled 4-inch section of surface air cooler piping, removed from service this year due to severe corrosion. Picture taken August 2006.



1

2

Picture 2

3

This is the same 4-inch section of pipe as in picture #1 after it has been cleaned. The corrosion pitting is on the order of 0.080-0.110 inch deep.

4

5

Picture taken August 2006.



1

2

Picture 3

3

This is the same 4-inch section of pipe as in picture #2, showing the amount of corrosion on the end. Picture taken August 2006.

4



Picture 4

This is a typical section of 2 inch cooling water pipe that shows the amount of fouling present and the severity of localized corrosion after the pipe was cleaned. Picture taken August 2006.



Picture 5

This is the same section of 2-inch cooling water pipe shown in picture #4, showing how deep the localized corrosion has gone, resulting in over 90% wall loss. Picture taken August 2006.



1

2

Picture 6

3

This is the same section of 2-inch cooling water pipe as in picture #5,

4

showing how deep the corrosion penetrates the wall. Picture taken August

5

2006.

NEWFOUNDLAND & LABRADOR HYDRO HYDRO GENERATION PREVENTIVE MAINTENANCE CHECKSHEETS	Sheet: 1 of 2 Rev. No.: 4 Rev. Date: 01-03-15 Index No. 849 Binder #5
PM Checksheet No. : PM6-58748-MBDE Item No. & Description: 58748 - Generator - Unit No. 1 - BDE Type of Inspection: PM6 Department: Mechanical Asset Approval: Fred Burden Inspection Start Date: Insp. Comp. Date: Supervisor's Review Signature & Date: Planner's Review Signature & Date: Reference Drawing and Manuals: <i>B. J. J. 2004/04/20</i> <div style="float: right; text-align: right;"> <i>RKmg</i> <i>apr - 26/04</i> </div>	
ACTIVITIES (Initial Box Upon Completion)	REMARKS
<div> CRITICAL PARTS INSPECTION </div> <div style="margin-top: 10px;"> 1. <u>Generator Brakes</u> Responsibility - Mechanical Maintenance "A" a) Check brake pads thickness and record: _____ (EO) Minimum wear surface is 1/4". <i>1/2</i> b) Check brake pads for cracks. Report to supervisor immediately if pads need replacement. (EO) c) Check brake track for excessive scouring or warpage. (EO) d) Check spring retaining nuts for looseness, missing set screws. Re-torque. (EO) e) Grease brake cylinders. Check for excessive leakage. (EO) f) Check air pipes for leaks. (EO) g) If unit shut down in excess of 48 hours, jack unit. (EO) <i>WG</i> </div> <div style="margin-top: 20px;"> 2. <u>Guide Bearing</u> Responsibility - Mechanical Maintenance "A" a) Check calibration of oil level system with P&C. (RW) b) Clean external bearing assembly. Check for leaks, loose bolts. (EO) c) Check water inlet to bearing coolers for leaks. (EO) d) Clean orifice on generator cooling water Rosemount Transducer. (EO) e) Check Rosemount in Control Room or T/G panel. (EO) Record: Normal <u>454 LPM</u> Actual <u>640 LPM</u> </div>	

JDE Item No & Description: 58748 - Generator - Unit No. 1 - BDE Type of Inspection: PM6 Department: Mechanical	Sheet 2 of 2 Rev. #: 4 Rev. Date: 01-03-15 Index No.: 849 Binder # 5
ACTIVITIES (Initial Box Upon Completion)	REMARKS
<p>ROUTINE PM INSPECTION</p> <ol style="list-style-type: none"> 1. Check SAC for leaks. (EO) 2. Clean orifices on coolers - North & South. (EO) 3. Check Rosemount in Control Room. (EO) <p><u>Record North SAC:</u></p> <p>Normal <u>1100 LPM</u> Actual <u>970 LPM</u></p> <p><u>Record South SAC:</u></p> <p>Normal <u>1100 LPM</u> Actual <u>996 LPM</u></p> <ol style="list-style-type: none"> 4. Take oil sample and forward to Engineering for analysis. (EO) 	

NEWFOUNDLAND & LABRADOR HYDRO HYDRO GENERATION PREVENTIVE MAINTENANCE CHECKSHEETS	Sheet: 1 of 2 Rev. No.: 4 Rev. Date: 01-03-15 Index No. 849 Binder #5
PM Checksheet No. : PM6-58748-MBDE Item No. & Description: 58748 - Generator - Unit No. 1 - BDE Type of Inspection: PM6 Department: Mechanical Inspection Start Date: 2005/03/21 Supervisor's Review Signature & Date: <i>[Signature]</i> 2005/04/01 Reference Drawing and Manuals:	
Asset Approval: Fred Burden Insp. Comp. Date: 2005/04/01 Planner's Review Signature & Date: <i>[Signature]</i> 05/04/11	

ACTIVITIES (Initial Box Upon Completion)	REMARKS
CRITICAL PARTS INSPECTION	
1. <u>Generator Brakes</u>	
Responsibility - Mechanical Maintenance "A"	
a) Check brake pads thickness and record: _____ Minimum wear surface is 1/4".	<i>Good</i>
b) Check brake pads for cracks. Report to supervisor immediately if pads need replacement.	<i>changed one set of pads on Axis 2. 2005-03-28</i>
c) Check brake track for excessive scouring or warpage.	<i>Good</i>
d) Check spring retaining nuts for looseness, missing set screws. Re-torque.	<i>Good</i>
e) Grease brake cylinders. Check for excessive leakage.	<i>Greased - 2005-03-24</i>
f) Check air pipes for leaks.	<i>Good</i>
g) If unit shut down in excess of 48 hours, jack unit.	<i>(RW) BT</i>
2. <u>Guide Bearing</u>	
Responsibility - Mechanical Maintenance "A"	
a) Check calibration of oil level system with P&C.	<i>(RW) BT</i>
b) Clean external bearing assembly. Check for leaks, loose bolts.	<i>2005-03-23</i>
c) Check water inlet to bearing coolers for leaks.	<i>2005-03-23</i>
d) Clean orifice on generator cooling water Rosemount Transducer.	<i>(RW) BT</i>
e) Check Rosemount in Control Room or T/G panel. Record: Normal <u>454 LPM</u> Actual <u>601</u>	<i>(RW) BT</i>

JDE Item No & Description: 58748 - Generator - Unit No. 1 - BDE Type of Inspection: PM6 Department: Mechanical	Sheet 2 of 2 Rev. #: 4 Rev. Date: 01-03-15 Index No.: 849 Binder #5
ACTIVITIES (Initial Box Upon Completion)	REMARKS
<p>ROUTINE PM INSPECTION</p> <ol style="list-style-type: none"> 1. Check SAC for leaks. <i>KM (50)</i> 2. Clean orifices on coolers - North & South. <i>KM (50)</i> 3. Check Rosemount in Control Room. <i>KM (50)</i> <p><u>Record North SAC:</u></p> <p>Normal <u>1100 LPM</u> Actual <i>903</i></p> <p><u>Record South SAC:</u></p> <p>Normal <u>1100 LPM</u> Actual <i>620</i></p> <ol style="list-style-type: none"> 4. Take oil sample and forward to Engineering for analysis. <i>N.E (BL)</i> 	<p><i>2005-02-24</i></p>

JDE Item No. & Description: 58613 - Generator - Unit No. 2 - BDE Type of Inspection: PM6 Department: Mechanical	Sheet 2 of 2 Rev. #: 4 Rev. Date: 01-03-15 Index No.: 850 Binder #5
ACTIVITIES (Initial Box Upon Completion)	REMARKS
<p>ROUTINE PM INSPECTION</p> <ol style="list-style-type: none"> 1. Check SAC for leaks. <i>(KM WC)</i> 2. Clean orifices on coolers - North & South. <i>(KM WC)</i> 3. Check Rosemount in Control Room. <i>(KM WC)</i> <p><u>Record North SAC:</u></p> <p>Normal <u>1100 LPM</u> Actual</p> <p><u>Record South SAC:</u></p> <p>Normal <u>1100 LPM</u> Actual</p> <ol style="list-style-type: none"> 4. Take oil sample and forward to Engineering for analysis. <i>(KM WC)</i> 	<p>1022 LPM</p> <p>1000 LPM</p>

**NEWFOUNDLAND & LABRADOR HYDRO
HYDRO GENERATION
PREVENTIVE MAINTENANCE CHECKSHEETS**

Sheet: 1 of 2
Rev. No.: 4
Rev. Date: 01-03-15
Index No. 850 Binder #5

PM Checksheet No. : PM6-58613-MBDE

Item No. & Description: 58613 - Generator - Unit No. 2 - BDE

Type of Inspection: PM6

Department: Mechanical

Inspection Start Date:

Supervisor's Review Signature & Date:

Reference Drawing and Manuals:

Asset Approval: Fred Burden

Insp. Comp. Date:

Planner's Review Signature & Date:

R King 05/05/13

2005/04/18
P. J. 05/05/03 P. J.

ACTIVITIES (Initial Box Upon Completion)

REMARKS

CRITICAL PARTS INSPECTION

1. Generator Brakes

Responsibility - Mechanical Maintenance "A"

- a) Check brake pads thickness and record: 7/16
Minimum wear surface is 1/4".
- b) Check brake pads for cracks. Report to supervisor immediately if pads need replacement.
- c) Check brake track for excessive scouring or warpage.
- d) Check spring retaining nuts for looseness, missing set screws. Re-torque.
- e) Grease brake cylinders. Check for excessive leakage.
- f) Check air pipes for leaks.
- g) If unit shut down in excess of 48 hours, jack unit.

(E0)
BF
AO
(EO)
BL

(EO)
BF
AO
BL

(AO)
BF
EO
BL

(AO)
BF
EO
BL

(EO)
BF
AO
BL

(EM)

AL

unit Jacked

2. Guide Bearing

Responsibility - Mechanical Maintenance "A"

- a) Check calibration of oil level system with P&C.
- b) Clean external bearing assembly. Check for leaks, loose bolts.
- c) Check water inlet to bearing coolers for leaks.
- d) Clean orifice on generator cooling water Rosemount Transducer.
- e) Check Rosemount in Control Room or T/G panel.
Record: Normal 454 LPM Actual _____

BF
(SO)
(AO
EO)
BF
AO
(EO
OL)
(AO
EO)
(BF

657 LPM

JDE Item No. & Description: 58613 - Generator - Unit No. 2 - BDE Type of Inspection: PM6 Department: Mechanical	Sheet 2 of 2 Rev. #: 4 Rev. Date: 01-03-15 Index No.: 850 Binder # 5
ACTIVITIES (Initial Box Upon Completion)	REMARKS
<p>ROUTINE PM INSPECTION</p> <ol style="list-style-type: none"> 1. Check SAC for leaks. (50) B.L. 2. Clean orifices on coolers - North & South. (50) B.L. 3. Check Rosemount in Control Room. (50) B.L. <p><u>Record North SAC:</u></p> <p>Normal <u>1100 LPM</u> Actual 997</p> <p><u>Record South SAC:</u></p> <p>Normal <u>1100 LPM</u> Actual 855</p> <ol style="list-style-type: none"> 4. Take oil sample and forward to Engineering for analysis. (20) A.O. 	