

B-51 Replace Battery Chargers, \$71,600

Q. Provide a copy of the review that was conducted regarding the maintenance history on battery chargers.

A. The following table contains a summary of the review of the history of battery charger problems experienced in recent years.

Location	Battery Charger Failure Description	Charger Mfg	Year	Planned Replacement Year
Sunnyside	Repairs in 2003	Staticon	1985	2007
Long Hr.	Repairs in 2003	Staticon	1979	2007
Western Avalon	Repairs in 2002 and 2005	Staticon	1986	2006
Hardwoods	Repairs in 2003 and 2004	Staticon	1992	2008
Stony Brook	Repairs in 2004	Staticon	1989	2008
Grand Falls	Repairs in 2004 and 2005	Staticon	1985	2006
Bay d’Espoir	Repairs in 2001	Cigentic	1981	2006
Howley	Repairs in 2001 and 2002	Cigentic	1981	2007
Deer Lake	Repairs in 1999, 2002,2003, and 2004	Cigentic	1980	2006

It was through the analysis of this data that the conclusion was made to replace the chargers at the Howley, Sunnyside and Long Harbour terminal stations.