

1 **B-65 Replace Diesel Unit 290 & Upgrade Fuel Storage System, Williams**  
2 **Harbour, \$479,300**

3 Q. Over what period of time have the tanks and dykes at Williams Harbour not  
4 been compliant with legislation? Please indicate the legislation requiring  
5 compliance.

6

7

8 A. The legislation requiring compliance is the *Storage and Handling of Gasoline*  
9 *and Associated Products Regulations, 2003*. The existing tanks pre-date the  
10 current legislation.