

Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed June 24, 2014

- → As of 1717 hours, April 10, 2014, Holyrood Unit 3 removed from service for annual maintenance (150 MW).
- → As of 0800 hours, May 21, 2014, Holyrood Unit 2 removed from service for annual maintenance (165 MW).
- → As of 1554 hours, May 24, 2014, Bay d'Espoir Unit 3 removed from service for annual maintenance (76.5 MW).
- As of 0858 hours, June 13, 2014, Stephenville Gas Turbine End A removed from service for annual maintenance (25 MW). \rightarrow
- → As of 0737 hours, June 15, 2014, Cat Arm Unit 1 removed from service for annual maintenance (67 MW).
- As of 0900 hours, June 18, 2014, Holyrood Unit 1 derated to 130 MW based on latest load test results (from 170 MW).

June 23, 2014 NLH System Outlook ³			Five-Day Forecast	Temperature (°C)		NLH System Demand (MW)	
				Morning	Evening	Morning	Evening
Available NLH System Supply: ⁴	1,060	MW	Monday, June 23, 2014	11	19	625	575
Current St. John's Temperature:	9	°C	Tuesday, June 24, 2014	16	21	600	550
Current St. John's Windchill:	N/A	°C	Wednesday, June 25, 2014	15	17	625	600
NLH System Peak Demand Forecast:	625	MW	Thursday, June 26, 2014	14	15	625	625
			Friday, June 27, 2014	14	13	625	600

- Notes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 - 2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as underfrequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Underfrequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
 - As of 0800 Hours. 3.
 - Gross output including station service at Holyrood (24.5 MW) and improved hydraulic output due to water levels (35 MW). Includes Nalcor Exploits, Star Lake, 4. Rattle Brook, CBPP Co-Gen. Excludes wind generation and DLP Secondary.

Section 3 Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak					
	11:25	675 MW			
orecast NLH System Island Interconnected Peak Demand		625 MW			
ctual Total Island Peak Demand ²	12:00	791 MW			
orecast Total Island Peak Demand		775 MW			
- -	Previous Day Actual Peak and Current Day For Actual NLH System Island Interconnected Peak Demand ¹ Forecast NLH System Island Interconnected Peak Demand Actual Total Island Peak Demand ² Forecast Total Island Peak Demand	Previous Day Actual Peak and Current Day Forecast Peak Actual NLH System Island Interconnected Peak Demand ¹ 11:25 Forecast NLH System Island Interconnected Peak Demand 11:25 Actual Total Island Peak Demand ² 12:00			