

Newfoundland Labrador Hydro (NLH)

- →
- → As of 1717 hours, April 10, 2014, Holyrood Unit 3 removed from service for annual maintenance (150 MW).
- → As of 0800 hours, May 21, 2014, Holyrood Unit 2 removed from service for annual maintenance (165 MW).
- → As of 1554 hours, May 24, 2014, Bay d'Espoir Unit 3 removed from service for annual maintenance (76.5 MW).
- → As of 0858 hours, June 13, 2014, Stephenville Gas Turbine End A removed from service for annual maintenance (25 MW).
- → As of 0010 hours, July 02, 2014, Hardwoods Gas Turbine End A unavailable (25 MW).
- As of 1800 hours, July 04, 2014, Stephenville Gas Turbine End B derated to 14 MW (25 MW). →
- → As of 0755 hours, July 06, 2014, Bay d'Espoir Unit 4 removed from service for annual maintenance (76.5 MW).
- At 1526 hours, July 07, 2014, Upper Salmon Unit removed from service on a forced outage. Unit available at 1912 hours (84 MW).

Section 2 NLH System Island Interconnected Supply and Demand									
July 8, 2014 NLH System Outlook <sup>3</sup>			Five-Day Forecast	Temperature (°C)		NLH System Demand (MW)			
				Morning	Evening	Morning	Evening		
Available NLH System Supply: <sup>4</sup>	960	MW	Tuesday, July 08, 2014	13	20	625	575		
Current St. John's Temperature:	16	°C	Wednesday, July 09, 2014	15	21	625	625		
Current St. John's Windchill:	N/A	°C	Thursday, July 10, 2014	19	23	625	600		
NLH System Peak Demand Forecast:	625	MW	Friday, July 11, 2014	19	24	625	575		
			Saturday, July 12, 2014	19	23	575	525		

## Supply Notes for July 08, 2014<sup>3</sup>

→

## At 0004 hours, July 08, 2014, Cat Arm Unit 1 removed from service on a forced outage (67 MW).

- Notes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
  - 2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as underfrequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Underfrequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
  - 3. As of 0800 Hours.

4. Gross output including station service at Holyrood (24.5 MW) and improved hydraulic output due to water levels (35 MW). Includes Nalcor Exploits, Star Lake, Rattle Brook, CBPP Co-Gen. Excludes wind generation and DLP Secondary.

Section 3 Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak							
July 8, 2014	Forecast NLH System Island Interconnected Peak Demand		625 MW				
July 7, 2014	Actual Total Island Peak Demand <sup>2</sup>	11:30	781 MW				
July 8, 2014	Forecast Total Island Peak Demand		725 MW				
	tem Island Interconnected is supplied by generation owned by NLH as well as NLH Power Pu and System Demand is supplied by NLH generation and NLH Power Purchases, plus generation						
Pulp & Pape	er to meet their respective supply needs.						