


Newfoundland Labrador Hydro (NLH)
Supply and Demand Status Report Filed August 11, 2014

Section 1
NLH System Island Interconnected Supply and Demand
Actual 24 Hour System Performance For August 08, 2014



Supply Notes for August 08, 2014

→ As of 0800 hours, May 21, 2014, Holyrood Unit 2 removed from service for annual maintenance (165 MW).

→ As of 1554 hours, May 24, 2014, Bay d'Espoir Unit 3 removed from service for annual maintenance (76.5 MW).

→ As of 0858 hours, June 13, 2014, Stephenville Gas Turbine End A removed from service for annual maintenance (25 MW).

→ As of 1800 hours, July 04, 2014, Stephenville Gas Turbine End B derated to 14 MW (25 MW).

→ As of 1139 hours, July 09, 2014, Cat Arm Unit 1 derated to 53 MW (67 MW).

→ As of 1100 hours, July 21, 2014, Holyrood Unit 1 removed from service for annual maintenance (170 MW).

→ As of 0347 hours, July 25, 2014, Hardwoods Gas Turbine unavailable due to a forced outage (50 MW).

→ As of 1124 hours, August 02, 2014, Bay d'Espoir Unit 7 derated to 120 MW (154 MW).

→ As of 1445 hours, August 03, 2014, Granite Canal Unit removed from service for annual maintenance (40 MW).

→ At 1210 hours, August 08, 2014, DLP Secondary power exports increased by approximately 60 MW following a sudden load reduction at the CBPP Mill. Exports returned to normal levels at 1250 hours.

→ At 1840 hours, August 08, 2014, Star Lake Unit tripped offline. Unit available for service at 1955 hours (18 MW).

Section 2 NLH System Island Interconnected Supply and Demand							
August 9, 2014 NLH System Outlook ³			Five-Day Forecast	Temperature (°C)		NLH System Demand (MW)	
				Morning	Evening	Morning	Evening
Available NLH System Supply: ⁴	1,025	MW	Saturday, August 09, 2014	16	18	600	575
Current St. John's Temperature:	18	°C	Sunday, August 10, 2014	15	17	600	600
Current St. John's Windchill:	N/A	°C	Monday, August 11, 2014	15	15	650	625
NLH System Peak Demand Forecast:	600	MW	Tuesday, August 12, 2014	16	16	625	600
			Wednesday, August 13, 2014	15	17	625	600

Supply Notes for August 09, 2014³

→

Notes:

1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as underfrequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Underfrequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
3. As of 0800 Hours.
4. Gross output including station service at Holyrood (24.5 MW) and improved hydraulic output due to water levels (35 MW). Includes Nalcor Exploits, Star Lake, Rattle Brook, CBPP Co-Gen. Excludes wind generation and DLP Secondary.

Section 3 Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak			
August 8, 2014	Actual NLH System Island Interconnected Peak Demand ¹	11:50	625 MW
August 9, 2014	Forecast NLH System Island Interconnected Peak Demand		600 MW
August 8, 2014	Actual Total Island Peak Demand ²	11:35	753 MW
August 9, 2014	Forecast Total Island Peak Demand		725 MW
Notes: 1. NLH System Island Interconnected is supplied by generation owned by NLH as well as NLH Power Purchases as detailed in Section 1 above. 2. Total Island System Demand is supplied by NLH generation and NLH Power Purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper to meet their respective supply needs.			