
## **Newfoundland Labrador Hydro (NLH)** Supply and Demand Status Report Filed October 24, 2014



## Supply Notes for October 23, 2014

- As of 0858 hours, June 13, 2014, Stephenville Gas Turbine End A removed from service for annual maintenance (25 MW).
- As of 1100 hours, July 21, 2014, Holyrood Unit 1 removed from service for annual maintenance (170 MW).
- As of 1653 hours, September 25, 2014, Bay d'Espoir Unit 3 removed from service on a forced outage (76.5 MW).
- As of 0826 hours, October 04, 2014, Stephenville Gas Turbine End B removed from service. Previously derated to 18 MW (25 MW).
- As of 0858 hours, October 05, 2014, Nalcor Exploits Unit 9 removed from service (30 MW).
- As of 1104 hours, October 06, 2014, Hinds Lake Unit removed from service for annual maintenance (75 MW).
- As of 0900 hours, October 22, 2014, Holyrood Unit 2 derated to 150 MW (170 MW).
- As of 1641 hours, October 22, 2014, Holyrood Unit 3 derated to 135 MW (150 MW).
- At 2245 hours, October 23, 2014, Cat Arm Unit 1 returned to service (67 MW).

Section 2  NLH System Island Interconnected Supply and Demand									
October 24, 2014 NLH System Outlook <sup>3</sup>			Five-Day Forecast	Temperature (°C)		NLH System Demand (MW)			
				Morning	Evening	Morning	Evening		
Available NLH System Supply:4	1,230	MW	Friday, October 24, 2014	9	10	825	800		
Current St. John's Temperature:	9	°C	Saturday, October 25, 2014	9	9	825	850		
Current St. John's Windchill:	N/A	°C	Sunday, October 26, 2014	9	10	775	800		
NLH System Peak Demand Forecast:	825	MW	Monday, October 27, 2014	10	9	800	875		
			Tuesday, October 28, 2014	7	4	875	900		

## Supply Notes for October 24, 2014

- Notes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
  - 2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as underfrequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Underfrequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.

  - 4. Gross output including station service at Holyrood (24.5 MW) and improved hydraulic output due to water levels (35 MW). Includes Nalcor Exploits, Star Lake, Rattle Brook, CBPP Co-Gen. Excludes wind generation and DLP Secondary.

Section 3 Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak							
October 23, 2014	Actual NLH System Island Interconnected Peak Demand <sup>1</sup>	08:35	887 MW				
October 24, 2014	Forecast NLH System Island Interconnected Peak Demand		825 MW				
October 23, 2014	Actual Total Island Peak Demand <sup>2</sup>	08:35	930 MW				
October 24, 2014	Forecast Total Island Peak Demand		925 MW				

- Notes: 1. NLH System Island Interconnected is supplied by generation owned by NLH as well as NLH Power Purchases as detailed in Section 1 above.
  - 2. Total Island System Demand is supplied by NLH generation and NLH Power Purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper to meet their respective supply needs.