Section 1 Island Interconnected System Supply and Demand Actual 24 Hour System Performance For Thursday, January 08, 2015 2000 1800 (M) 1600 1400 1200 1000 **Peak Demand** 1,608 MW @ 17:05 800 600 21:0 21:10 22:30 23:15 0:00 ——Island Interconnected System Supply ——Island Interconnected System Demand Supply Notes for January 08, 2015^{1,2} As of 1000 hours, November 21, 2014, Nalcor Exploits Unit 4 unavailable due to a forced outage (30 MW). Net impact to system 4 MW (the excess Δ water utilised by other Nalcor Grand Falls Units 5 to 8). As of 1315 hours, December 15, 2014, the Stephenville Gas Turbine End 'B' unavailable (25 MW). B As of 0730 hours, January 07, 2015, the Nalcor Grand Falls plant derating (ice conditions) has been updated to a 3 MW net impact loss to the С

Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Friday, January 09, 2015

system.

At 1100 hours, January 08, 2015, Hardwoods Gas Turbine Ends 'A & B' unavailable due to a forced outage (50 MW). D

Ε At 1150 hours, January 08, 2015, Hardwoods Gas Turbine End 'A' returned to service (25 MW).

At 1655 hours, January 08, 2015, Hardwoods Gas Turbine End 'B' returned to service (25 MW).

Fri, Jan 09, 2015 Island S	System Outlook ³		Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)	
				Morning	Evening	Forecast	Adjusted
Available Island System Supply: ⁵	1,875	MW	Friday, January 09, 2015	-11	-7	1,625	1,525
NLH Generation: ⁴	1,545	MW	Saturday, January 10, 2015	4	-5	1,460	1,365
NLH Power Purchases:	115	MW	Sunday, January 11, 2015	-10	-7	1,550	1,450
Other Island Generation:	215	MW	Monday, January 12, 2015	-8	-6	1,550	1,450
Current St. John's Temperature:	-15	°C	Tuesday, January 13, 2015	-3	-8	1,525	1,425
Current St. John's Windchill:	-22	°C	Wednesday, January 14, 2015	-10	-6	1,525	1,425
7-Day Island Peak Demand Forecast:	1,625	MW	Thursday, January 15, 2015	-5	-3	1,420	1,325

Notes:	1.	Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact
		customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands
		are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.

- 2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as underfrequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Underfrequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
- 3. As of 0800 Hours.

- 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
- 5. Gross output from all Island sources (including Note 4).
- 6. Adjusted for CBP&P interruptible load (when applicable) and the impact of voltage reduction.

	Section 3 Island Peak Demand Inf Previous Day Actual Peak and Curre		
Thu, Jan 08, 2015	Actual Island Peak Demand ⁷	17:05	1,608 MW
Fri, Jan 09, 2015	Forecast Island Peak Demand		1,625 MW