

Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Thursday, June 11, 2015

As of 0808 hours, May 27, 2015, Bay d'Espoir Unit 5 removed from service for annual maintenance (76.5 MW).

- As of 0808 hours, May 27, 2015, Bay d'Espoir Unit 6 removed from service for annual maintenance (76.5 MW).
- As of 0824 hours, May 29, 2015, Hardwoods Gas Turbine End A unavailable (25 MW).
- As of 1440 hours, June 06, 2015, Holyrood Unit 2 removed from service for annual maintenance (170 MW). G
- Н As of 0946 hours, June 08, 2015, Star Lake Unit removed from service (18 MW).
 - As of 1109 hours, June 09, 2015, Holyrood Combustion Turbine removed from service for maintenance (123.5 MW).
 - At 0616 hours, June 10, 2015, Granite Canal Unit removed from service for maintenance (40 MW)

Section 2 Island Interconnected Supply and Demand								
Thu, Jun 11, 2015 Island System Outlook ³			Seven-Day Forecast	-	erature C)	Island System Daily Peak Demand (MW)		
				Morning	Evening	Forecast		
Available Island System Supply: ⁵	1,220	MW	Thursday, June 11, 2015	10	15	830		
NLH Generation: ⁴	930	MW	Friday, June 12, 2015	15	15	820		
NLH Power Purchases:	75	MW	Saturday, June 13, 2015	14	12	800		
Other Island Generation:	215	MW	Sunday, June 14, 2015	11	8	835		
Current St. John's Temperature:	12	°C	Monday, June 15, 2015	6	8	915		
Current St. John's Windchill:	N/A	°C	Tuesday, June 16, 2015	12	11	820		
7-Day Island Peak Demand Forecast:	915	MW	Wednesday, June 17, 2015	11	15	840		

Supply Notes For June 11, 2015

Ε

- Notes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 - 2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as underfrequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Underfrequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
 - 3. As of 0800 Hours.
 - 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 - 5. Gross output from all Island sources (including Note 4).

Section 3 Island Peak Demand Information						
Wed, Jun 10, 2015	Actual Island Peak Demand	08:15	816 MW			
Thu, Jun 11, 2015	Forecast Island Peak Demand		830 MW			
Notes: 7. Island Demand	is supplied by NLH generation and purchases, plus generation owned an	d operated by Newfoundland Power and Corner Br	ook Pulp & Paper (Deer Lake			
Power, DLP).						