


Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Tuesday, May 24, 2016

Section 1 Island Interconnected System Supply and Demand Actual 24 Hour System Performance For Friday, May 20, 2016



Supply Notes For May 20, 2016

- 1,2
- A** As of 1956 hours, January 14, 2016, Nalcor Exploits Grand Falls Unit 7 unavailable. No net impact to the Island Interconnected System.
- B** As of 0732 hours, February 29, 2016, Hardwoods Gas Turbine derated to 38 MW (50 MW). End A 19 MW, End B 25 MW.
- C** As of 1526 hours, March 26, 2016, Stephenville Gas Turbine End A unavailable (25 MW).
- D** As of 1029 hours, April 15, 2016, Holyrood Unit 3 unavailable (150 MW).
- E** As of 2209 hours, April 30, 2016, Holyrood Unit 1 derated to 120 MW (170 MW).
- F** As of 1200 hours, May 07, 2016, Holyrood Unit 2 derated to 120 MW (170 MW).
- G** As of 0937 hours, May 10, 2016, Bay d'Espoir Unit 6 unavailable (76.5 MW).
- H** As of 0724 hours, May 16 2016, Nalcor Exploits Grand Falls Unit 4 (30 MW) unavailable. Net impact to the Island Interconnected System is 7 MW.
- I** As of 2028 hours, May 19, 2016, Bay d'Espoir Unit 7 unavailable (154.4 MW).

Section 2 Island Interconnected Supply and Demand

Sat, May 21, 2016 Island System Outlook ³		Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)
			Morning	Evening	
Available Island System Supply: ⁵	1,470 MW	Saturday, May 21, 2016	9	14	810
NLH Generation: ⁴	1,175 MW	Sunday, May 22, 2016	4	3	950
NLH Power Purchases: ⁶	95 MW	Monday, May 23, 2016	6	9	955
Other Island Generation:	200 MW	Tuesday, May 24, 2016	10	14	835
Current St. John's Temperature:	10 °C	Wednesday, May 25, 2016	15	17	770
Current St. John's Windchill:	N/A °C	Thursday, May 26, 2016	16	14	785
7-Day Island Peak Demand Forecast:	955 MW	Friday, May 27, 2016	15	13	800

Supply Notes For May 21, 2016

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Under frequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
 3. As of 0800 Hours.
 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 5. Gross output from all Island sources (including Note 4).
 6. NLH Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Vale capacity assistance (when applicable), and Wind Generation.

Section 3 Island Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak

Fri, May 20, 2016	Actual Island Peak Demand ⁸	08:20	849 MW
Sat, May 21, 2016	Forecast Island Peak Demand		810 MW

Notes: 8. Island Demand is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).