


Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Monday, May 30, 2016

Section 1 Island Interconnected System Supply and Demand Actual 24 Hour System Performance For Friday, May 27, 2016



Supply Notes For May 27, 2016

- A As of 1956 hours, January 14, 2016, Nalcor Exploits Grand Falls Unit 7 unavailable. No net impact to the Island Interconnected System.
- B As of 0732 hours, February 29, 2016, Hardwoods Gas Turbine derated to 38 MW (50 MW). End A 19 MW, End B 25 MW.
- C As of 1526 hours, March 26, 2016, Stephenville Gas Turbine End A unavailable (25 MW).
- D As of 1029 hours, April 15, 2016, Holyrood Unit 3 unavailable (150 MW).
- E As of 2209 hours, April 30, 2016, Holyrood Unit 1 derated to 120 MW (170 MW).
- F As of 0937 hours, May 10, 2016, Bay d'Espoir Unit 6 unavailable (76.5 MW).
- G As of 0724 hours, May 16 2016, Nalcor Exploits Grand Falls Unit 4 (30 MW) unavailable. Net impact to the Island Interconnected System is 7 MW.
- H As of 1642 hours, May 21, 2016, Bay d'Espoir Unit 1 unavailable (76.5 MW).
- I As of 1642 hours, May 21, 2016, Bay d'Espoir Unit 2 unavailable (76.5 MW).
- J As of 2243 hours, May 26, 2016, Holyrood Unit 2 derated to 50 MW (170 MW).

Section 2 Island Interconnected Supply and Demand

Sat, May 28, 2016 Island System Outlook ³		Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW) Forecast
			Morning	Evening	
Available Island System Supply: ⁵	1,410 MW	Saturday, May 28, 2016	3	2	1,005
NLH Generation: ⁴	1,105 MW	Sunday, May 29, 2016	2	1	1,065
NLH Power Purchases: ⁶	95 MW	Monday, May 30, 2016	8	9	890
Other Island Generation:	210 MW	Tuesday, May 31, 2016	9	15	900
Current St. John's Temperature:	3 °C	Wednesday, June 01, 2016	13	5	920
Current St. John's Windchill:	N/A °C	Thursday, June 02, 2016	6	5	930
7-Day Island Peak Demand Forecast:	1,065 MW	Friday, June 03, 2016	5	5	1,020

Supply Notes For May 28, 2016

- Notes:
- Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 - Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Under frequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
 - As of 0800 Hours.
 - Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 - Gross output from all Island sources (including Note 4).
 - NLH Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Vale capacity assistance (when applicable), and Wind Generation.

Section 3 Island Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak

Fri, May 27, 2016	Actual Island Peak Demand ⁸	08:05	996 MW
Sat, May 28, 2016	Forecast Island Peak Demand		1,005 MW

- Notes: 8. Island Demand is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).