


**Newfoundland Labrador Hydro (NLH)
Supply and Demand Status Report Filed Tuesday, March 07, 2017**

**Section 1
Island Interconnected System Supply and Demand
Actual 24 Hour System Performance For Monday, March 06, 2017**



Supply Notes For March 06, 2017

1,2

- A As of 1513 hours, February 09, 2017, Stephenville Gas Turbine available at 38 MW (50 MW).
 B As of 1238 hours, February 19, 2017, Hardwoods Gas Turbine available at 25 MW (50 MW).
 C At 0317 hours, March 06, 2017, Upper Salmon Unit available (84 MW).
 D At 0700 hours, March 06, 2017, Holyrood Unit 1 available at 140 MW (170 MW).
 E At 0700 hours, March 06, 2017, Holyrood Unit 2 available at 140 MW (170 MW).
 F At 1228 hours, March 06, 2017, Upper Salmon Unit unavailable (84 MW).

**Section 2
Island Interconnected Supply and Demand**

Tue, Mar 07, 2017	Island System Outlook ³	Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)	
			Morning	Evening	Forecast	Adjusted ⁷
Available Island System Supply: ⁵	1,840 MW	Tuesday, March 07, 2017	-3	-4	1,460	1,352
NLH Generation: ⁴	1,510 MW	Wednesday, March 08, 2017	-4	-1	1,445	1,337
NLH Power Purchases: ⁶	120 MW	Thursday, March 09, 2017	2	0	1,315	1,209
Other Island Generation:	210 MW	Friday, March 10, 2017	-1	-4	1,370	1,263
Current St. John's Temperature:	-4 °C	Saturday, March 11, 2017	-6	-7	1,435	1,327
Current St. John's Windchill:	-12 °C	Sunday, March 12, 2017	-7	-6	1,435	1,327
7-Day Island Peak Demand Forecast:	1,460 MW	Monday, March 13, 2017	-4	-3	1,395	1,288

Supply Notes For March 07, 2017

3

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Under frequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
 3. As of 0800 Hours.
 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 5. Gross output from all Island sources (including Note 4).
 6. NLH Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Vale capacity assistance (when applicable), and Wind Generation.
 7. Adjusted for CBP&P, Praxair and Vale interruptible load as well as the impact of voltage reduction, when applicable.

**Section 3
Island Peak Demand Information
Previous Day Actual Peak and Current Day Forecast Peak**

Mon, Mar 06, 2017	Actual Island Peak Demand ⁸	08:00	1,419 MW
Tue, Mar 07, 2017	Forecast Island Peak Demand		1,460 MW

- Notes: 8. Island Demand is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).