


Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Friday, August 25, 2017

Section 1 Island Interconnected System Supply and Demand Actual 24 Hour System Performance For Thursday, August 24, 2017



Supply Notes For August 24, 2017

- 1,2
- A** As of 1858 hours, June 22, 2017, Stephenville Gas Turbine available at 25 MW (50 MW).
B As of 0938 hours, June 23, 2017, Holyrood Unit 1 unavailable due to planned outage 120 MW (170 MW).
C As of 0827 hours, July 31, 2017, Holyrood Unit 2 unavailable due to planned outage 165 MW (170 MW).
D As of 1250 hours, August 06, 2017, Upper Salmon Unit unavailable due to planned outage (84 MW).
E As of 1333 hours, August 17, 2017, Hardwoods Gas Turbine available at 25 MW (50 MW).

Section 2 Island Interconnected Supply and Demand

Fri, Aug 25, 2017		Island System Outlook ³	Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW) Forecast
				Morning	Evening	
Available Island System Supply: ⁵	1,500	MW	Friday, August 25, 2017	20	19	790
NLH Generation: ⁴	1,220	MW	Saturday, August 26, 2017	20	10	835
NLH Power Purchases: ⁶	95	MW	Sunday, August 27, 2017	10	12	815
Other Island Generation:	185	MW	Monday, August 28, 2017	13	15	810
Current St. John's Temperature:	19	°C	Tuesday, August 29, 2017	15	16	815
Current St. John's Windchill:	N/A	°C	Wednesday, August 30, 2017	15	16	805
7-Day Island Peak Demand Forecast:	835	MW	Thursday, August 31, 2017	15	12	810

Supply Notes For August 25, 2017

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Under frequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
 3. As of 0800 Hours.
 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 5. Gross output from all Island sources (including Note 4).
 6. NLH Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Vale capacity assistance (when applicable), and Wind Generation.

Section 3 Island Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak

Thu, Aug 24, 2017	Actual Island Peak Demand ⁸	11:40	770 MW
Fri, Aug 25, 2017	Forecast Island Peak Demand		790 MW

- Notes: 8. Island Demand is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).