


Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Tuesday, January 08, 2019

Section 1 Island Interconnected System Supply, Demand & Exports Actual 24 Hour System Performance For Monday, January 07, 2019



Supply Notes For January 07, 2019

1,2

A As of 1615 hours, December 19, 2018, Holyrood Unit 1 available at 162 MW (170 MW).

Section 2 Island Interconnected Supply and Demand

Tue, Jan 08, 2019	Island System Outlook ³		Seven-Day Forecast		Temperature (°C)		Island System Daily Peak Demand (MW)	
					Morning	Evening	Forecast	Adjusted ⁷
Available Island System Supply: ⁵	2,131	MW	Tuesday, January 08, 2019	-6	-7	1,585	1,481	
NLH Island Generation: ⁴	1,685	MW	Wednesday, January 09, 2019	-4	-4	1,485	1,382	
NLH Island Power Purchases: ⁶	140	MW	Thursday, January 10, 2019	-2	1	1,500	1,397	
Other Island Generation:	205	MW	Friday, January 11, 2019	0	-1	1,410	1,308	
ML/LIL Imports:	101	MW	Saturday, January 12, 2019	-2	-4	1,440	1,337	
Current St. John's Temperature & Windchill: -7 °C	-17	°C	Sunday, January 13, 2019	-4	-5	1,510	1,407	
7-Day Island Peak Demand Forecast:	1,585	MW	Monday, January 14, 2019	-7	-4	1,585	1,481	

Supply Notes For January 08, 2019

3

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. Due to the Island system having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units there may be a requirement for some customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes. With the activation of the Maritime Link frequency controller during the winter of 2018, UFLS events have occurred less frequently.
 3. As of 0800 Hours.
 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 5. Gross output from all Island sources (including Note 4).
 6. NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 7. Adjusted for curtailable load, market activities and the impact of voltage reduction when applicable.

Section 3 Island Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak

Mon, Jan 07, 2019	Actual Island Peak Demand ⁸	17:15	1,437 MW
Tue, Jan 08, 2019	Forecast Island Peak Demand		1,585 MW

Notes: 8. Island Demand / LIL / ML Exports (where applicable) is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).