


Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Wednesday, January 23, 2019

Section 1 Island Interconnected System Supply, Demand & Exports Actual 24 Hour System Performance For Tuesday, January 22, 2019



Supply Notes For January 22, 2019

1,2

A At 0823 hours, January 22, 2019, Holyrood Unit 1 available at 70 MW (170 MW).

B At 1855 hours, January 22, 2019, Holyrood Unit 1 available at 162 MW (170 MW).

Section 2 Island Interconnected Supply and Demand

Wed, Jan 23, 2019	Island System Outlook ³	Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)	
			Morning	Evening	Forecast	Adjusted ⁷
Available Island System Supply: ⁵	2,167 MW	Wednesday, January 23, 2019	-5	-5	1,450	1,347
NLH Island Generation: ⁴	1,685 MW	Thursday, January 24, 2019	-7	-1	1,480	1,377
NLH Island Power Purchases: ⁶	145 MW	Friday, January 25, 2019	4	5	1,325	1,224
Other Island Generation:	215 MW	Saturday, January 26, 2019	1	0	1,365	1,263
ML/LIL Imports:	122 MW	Sunday, January 27, 2019	-7	-5	1,465	1,362
Current St. John's Temperature & Windchill:	-6 °C	Monday, January 28, 2019	-1	2	1,485	1,382
7-Day Island Peak Demand Forecast:	1,550 MW	Tuesday, January 29, 2019	-4	-4	1,550	1,446

Supply Notes For January 23, 2019

3

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. Due to the Island system having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units there may be a requirement for some customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes. With the activation of the Maritime Link frequency controller during the winter of 2018, UFLS events have occurred less frequently.
 3. As of 0800 Hours.
 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 5. Gross output from all Island sources (including Note 4).
 6. NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 7. Adjusted for curtailable load, market activities and the impact of voltage reduction when applicable.

Section 3 Island Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak

Tue, Jan 22, 2019	Actual Island Peak Demand ⁸	17:25	1,322 MW
Wed, Jan 23, 2019	Forecast Island Peak Demand		1,450 MW

Notes: 8. Island Demand / LIL / ML Exports (where applicable) is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).