


**Newfoundland Labrador Hydro (NLH)
Supply and Demand Status Report Filed Thursday, January 31, 2019**

**Section 1
Island Interconnected System Supply, Demand & Exports
Actual 24 Hour System Performance For Wednesday, January 30, 2019**



Supply Notes For January 30, 2019

1,2

A As of 2146 hours, January 29, 2019, Holyrood Unit 1 unavailable due to planned outage 165 MW (170 MW).

**Section 2
Island Interconnected Supply and Demand**

Thu, Jan 31, 2019	Island System Outlook ³	Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)	
			Morning	Evening	Forecast	Adjusted ⁷
Available Island System Supply: ⁵	2,016 MW	Thursday, January 31, 2019	1	-2	1,405	1,303
NLH Island Generation: ⁴	1,525 MW	Friday, February 01, 2019	-7	-7	1,555	1,451
NLH Island Power Purchases: ⁶	140 MW	Saturday, February 02, 2019	-5	-6	1,530	1,426
Other Island Generation:	230 MW	Sunday, February 03, 2019	-8	-7	1,595	1,491
ML/LIL Imports:	121 MW	Monday, February 04, 2019	-9	-5	1,610	1,505
Current St. John's Temperature & Windchill:	0 °C -6 °C	Tuesday, February 05, 2019	-6	-2	1,525	1,421
7-Day Island Peak Demand Forecast:	1,610 MW	Wednesday, February 06, 2019	4	-3	1,440	1,337

Supply Notes For January 31, 2019

3

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. Due to the Island system having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units there may be a requirement for some customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes. With the activation of the Maritime Link frequency controller during the winter of 2018, UFLS events have occurred less frequently.
 3. As of 0800 Hours.
 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 5. Gross output from all Island sources (including Note 4).
 6. NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 7. Adjusted for curtailable load, market activities and the impact of voltage reduction when applicable.

**Section 3
Island Peak Demand Information
Previous Day Actual Peak and Current Day Forecast Peak**

Wed, Jan 30, 2019	Actual Island Peak Demand ⁸	08:20	1,479 MW
Thu, Jan 31, 2019	Forecast Island Peak Demand		1,405 MW

Notes: 8. Island Demand / LIL / ML Exports (where applicable) is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).