


**Newfoundland Labrador Hydro (NLH)
Supply and Demand Status Report Filed Thursday, April 16, 2020**

**Section 1
Island Interconnected System Supply, Demand & Exports
Actual 24 Hour System Performance For Wednesday, April 15, 2020**



Supply Notes For April 15, 2020

1,2

- A As of 0847 hours, March 19, 2020, Holyrood Diesels available at 8 MW (10 MW).
- B As of 1054 hours, March 31, 2020, Holyrood Unit 3 removed from service for economic dispatch (150 MW).
- C As of 1210 hours, April 13, 2020, Holyrood Gas Turbine unavailable due to planned outage (123.5 MW).
- D **At 1600 hours, April 15, 2020, Hinds Lake Unit unavailable (75 MW).**

**Section 2
Island Interconnected Supply and Demand**

Thu, Apr 16, 2020	Island System Outlook ³		Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)	
				Morning	Evening	Forecast	Adjusted ⁷
Available Island System Supply: ⁵	1,675	MW	Thursday, April 16, 2020	0	1	1,040	948
NLH Island Generation: ⁴	1,340	MW	Friday, April 17, 2020	-1	-2	1,125	1,032
NLH Island Power Purchases: ⁶	125	MW	Saturday, April 18, 2020	-1	-1	1,125	1,032
Other Island Generation:	210	MW	Sunday, April 19, 2020	0	0	1,125	1,032
ML/LIL Imports:	-	MW	Monday, April 20, 2020	3	3	1,140	1,047
Current St. John's Temperature & Windchill:	0 °C	N/A °C	Tuesday, April 21, 2020	3	2	1,050	958
7-Day Island Peak Demand Forecast:	1,140	MW	Wednesday, April 22, 2020	2	4	1,120	1,027

Supply Notes For April 16, 2020

3

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. Due to the Island system having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units there may be a requirement for some customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes. With the activation of the Maritime Link frequency controller during the winter of 2018, UFLS events have occurred less frequently.
 3. As of 0800 Hours.
 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 5. Gross output from all Island sources (including Note 4).
 6. NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 7. Adjusted for curtailable load, market activities and the impact of voltage reduction when applicable.

**Section 3
Island Peak Demand Information
Previous Day Actual Peak and Current Day Forecast Peak**

Wed, Apr 15, 2020	Actual Island Peak Demand ⁸	20:40	988 MW
Thu, Apr 16, 2020	Forecast Island Peak Demand		1,040 MW

- Notes: 8. Island Demand / LIL / ML Exports (where applicable) is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).