


**Newfoundland Labrador Hydro (NLH)
Supply and Demand Status Report Filed Wednesday, May 06, 2020**

**Section 1
Island Interconnected System Supply, Demand & Exports
Actual 24 Hour System Performance For Tuesday, May 05, 2020**



Supply Notes For May 05, 2020

1,2

- A As of 1245 hours, April 24, 2020, Holyrood Unit 3 unavailable due to planned outage (150 MW).
- B As of 1009 hours, May 01, 2020, Holyrood Unit 1 available but not operating (170 MW).
- C As of 1200 hours, May 03, 2020, Bay d'Espoir Unit 5 unavailable due to planned outage (76.5 MW).
- D At 1551 hours, May 05, 2020, Holyrood Diesels available at full capacity (10 MW).

**Section 2
Island Interconnected Supply and Demand**

Wed, May 06, 2020	Island System Outlook ³			Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)	
					Morning	Evening	Forecast	Adjusted ⁷
Available Island System Supply: ⁵	1,645	MW		Wednesday, May 06, 2020	4	3	1,030	1,030
NLH Island Generation: ⁴	1,295	MW		Thursday, May 07, 2020	2	4	1,045	1,045
NLH Island Power Purchases: ⁶	130	MW		Friday, May 08, 2020	7	4	975	975
Other Island Generation:	220	MW		Saturday, May 09, 2020	4	5	950	950
ML/LIL Imports:	-	MW		Sunday, May 10, 2020	6	3	995	995
Current St. John's Temperature & Windchill:	2 °C	N/A °C		Monday, May 11, 2020	4	4	995	995
7-Day Island Peak Demand Forecast:	1,045	MW		Tuesday, May 12, 2020	6	6	960	960

Supply Notes For May 06, 2020

3

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. Due to the Island system having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units there may be a requirement for some customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes. With the activation of the Maritime Link frequency controller during the winter of 2018, UFLS events have occurred less frequently.
 3. As of 0800 Hours.
 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 5. Gross output from all Island sources (including Note 4).
 6. NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 7. Adjusted for curtailable load, market activities and the impact of voltage reduction when applicable.

**Section 3
Island Peak Demand Information
Previous Day Actual Peak and Current Day Forecast Peak**

Tue, May 05, 2020	Actual Island Peak Demand ⁸	11:45	1,150 MW
Wed, May 06, 2020	Forecast Island Peak Demand		1,030 MW

- Notes: 8. Island Demand / LIL / ML Exports (where applicable) is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).