


**Newfoundland Labrador Hydro (NLH)  
Supply and Demand Status Report Filed Monday, November 16, 2020**

**Section 1  
Island Interconnected System Supply, Demand & Exports  
Actual 24 Hour System Performance For Sunday, November 15, 2020**



**Supply Notes For November 15, 2020**

- A As of 1134 hours, October 29, 2020, Hinds Lake Unit available at 65 MW (75 MW).
- B As of 1431 hours, November 08, 2020, Paradise River Unit unavailable due to planned outage (8 MW).
- C At 1136 hours, November 15, 2020, Holyrood Unit 3 available (150 MW).
- D At 1705 hours, November 15, 2020, Stephenville Gas Turbine available (50 MW).
- E At 1827 hours, November 15, 2020, Bay d'Espoir Unit 5 unavailable due to planned outage (76.5 MW).

**Section 2  
Island Interconnected Supply and Demand**

Mon, Nov 16, 2020	Island System Outlook <sup>3</sup>	Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)	
			Morning	Evening	Forecast	Adjusted <sup>7</sup>
Available Island System Supply: <sup>5</sup>	1,895 MW	Monday, November 16, 2020	0	4	1,195	1,101
NLH Island Generation: <sup>4</sup>	1,600 MW	Tuesday, November 17, 2020	6	3	1,100	1,007
NLH Island Power Purchases: <sup>6</sup>	70 MW	Wednesday, November 18, 2020	3	0	1,145	1,052
Other Island Generation:	225 MW	Thursday, November 19, 2020	-2	-1	1,225	1,131
ML/LIL Imports:	- MW	Friday, November 20, 2020	-2	3	1,230	1,136
Current St. John's Temperature & Windchill:	0 °C -2 °C	Saturday, November 21, 2020	1	1	1,195	1,101
7-Day Island Peak Demand Forecast:	1,230 MW	Sunday, November 22, 2020	-4	-2	1,225	1,131

**Supply Notes For November 16, 2020**

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
  2. Due to the Island system having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units there may be a requirement for some customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes. With the activation of the Maritime Link frequency controller during the winter of 2018, UFLS events have occurred less frequently.
  3. As of 0800 Hours.
  4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
  5. Gross output from all Island sources (including Note 4).
  6. NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
  7. Adjusted for curtailable load, market activities and the impact of voltage reduction when applicable.

**Section 3  
Island Peak Demand Information  
Previous Day Actual Peak and Current Day Forecast Peak**

Sun, Nov 15, 2020	Actual Island Peak Demand <sup>8</sup>	16:55	1,154 MW
Mon, Nov 16, 2020	Forecast Island Peak Demand		1,195 MW

- Notes: <sup>8</sup> Island Demand / LIL / ML Exports (where applicable) is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).