


**Newfoundland Labrador Hydro (NLH)
Supply and Demand Status Report Filed Monday, December 14, 2020**

**Section 1
Island Interconnected System Supply, Demand & Exports
Actual 24 Hour System Performance For Saturday, December 12, 2020**



Supply Notes For December 12, 2020

^{1,2}

A As of 1520 hours, December 7, 2020, Holyrood Unit 2 available but not operating (170 MW).

B At 1821 hours, December 12, 2020, Holyrood Unit 2 unavailable (170 MW).

**Section 2
Island Interconnected Supply and Demand**

Sun, Dec 13, 2020	Island System Outlook ³		Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)		
				Morning	Evening	Forecast	Adjusted ⁷	
Available Island System Supply: ⁵	1,865	MW	Sunday, December 13, 2020	-2	-1	1,375	1,271	
NLH Island Generation: ⁴	1,525	MW	Monday, December 14, 2020	1	1	1,370	1,266	
NLH Island Power Purchases: ⁶	90	MW	Tuesday, December 15, 2020	3	-1	1,330	1,227	
Other Island Generation:	250	MW	Wednesday, December 16, 2020	-4	-4	1,435	1,330	
ML/LIL Imports:	-	MW	Thursday, December 17, 2020	-5	-3	1,375	1,271	
Current St. John's Temperature & Windchill:	-2	-5	°C	Friday, December 18, 2020	-2	-2	1,335	1,232
7-Day Island Peak Demand Forecast:	1,435	MW	Saturday, December 19, 2020	-3	-4	1,405	1,301	

Supply Notes For December 13, 2020

³

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. Due to the Island system having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units there may be a requirement for some customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes. With the activation of the Maritime Link frequency controller during the winter of 2018, UFLS events have occurred less frequently.
 3. As of 0800 Hours.
 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 5. Gross output from all Island sources (including Note 4).
 6. NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 7. Adjusted for curtailable load, market activities and the impact of voltage reduction when applicable.

**Section 3
Island Peak Demand Information
Previous Day Actual Peak and Current Day Forecast Peak**

Sat, Dec 12, 2020	Actual Island Peak Demand ⁸	17:10	1,246 MW
Sun, Dec 13, 2020	Forecast Island Peak Demand		1,375 MW

Notes: 8. Island Demand / LIL / ML Exports (where applicable) is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).