


**Newfoundland Labrador Hydro (NLH)  
Supply and Demand Status Report Filed Tuesday, July 06, 2021**

**Section 1  
Island Interconnected System Supply, Demand & Exports  
Actual 24 Hour System Performance For Monday, July 05, 2021**



**Supply Notes For July 05, 2021**

- A As of 0805 hours, April 09, 2021, Holyrood Unit 3 unavailable due to planned outage (150 MW).
- B As of 0804 hours, May 26, 2021, Holyrood Unit 1 unavailable due to planned outage (170 MW).
- C As of 0720 hours, June 26, 2021, Holyrood Unit 2 available but not operating (170 MW).
- D As of 1020 hours, June 28, 2021, Bay d'Espoir Unit 7 unavailable due to planned outage (154.4 MW).
- E As of 0931 hours, July 04, Granite Canal Unit unavailable due to planned outage (40 MW).
- F At 0702 hours, July 05, 2021, Hardwoods Gas Turbine unavailable due to planned outage (50 MW).
- G At 0801 hours, July 05, 2021, St. Anthony Diesel Plant available at 8 MW (9.7 MW).

**Section 2  
Island Interconnected Supply and Demand**

Tue, Jul 06, 2021	Island System Outlook <sup>3</sup>			Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)	
					Morning	Evening	Forecast	Adjusted <sup>7</sup>
Available Island System Supply: <sup>5</sup>	1,290	MW		Tuesday, July 06, 2021	13	20	755	755
NLH Island Generation: <sup>4</sup>	955	MW		Wednesday, July 07, 2021	17	17	750	750
NLH Island Power Purchases: <sup>6</sup>	120	MW		Thursday, July 08, 2021	16	10	780	780
Other Island Generation:	215	MW		Friday, July 09, 2021	12	12	750	750
ML/LIL Imports:	-	MW		Saturday, July 10, 2021	17	18	730	730
Current St. John's Temperature & Windchill:	11 °C	N/A	°C	Sunday, July 11, 2021	16	16	725	725
7-Day Island Peak Demand Forecast:	780	MW		Monday, July 12, 2021	16	15	750	750

**Supply Notes For July 06, 2021**

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
  2. Due to the Island system having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units there may be a requirement for some customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes. With the activation of the Maritime Link frequency controller during the winter of 2018, UFLS events have occurred less frequently.
  3. As of 0800 Hours.
  4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
  5. Gross output from all Island sources (including Note 4).
  6. NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
  7. Adjusted for curtailable load, market activities and the impact of voltage reduction when applicable.

**Section 3  
Island Peak Demand Information  
Previous Day Actual Peak and Current Day Forecast Peak**

Mon, Jul 05, 2021	Actual Island Peak Demand <sup>8</sup>	10:00	829 MW
Tue, Jul 06, 2021	Forecast Island Peak Demand		755 MW

Notes: 8. Island Demand / LIL / ML Exports (where applicable) is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).