

NLH Island Power Purchases:"		80	MW	Saturday, October 7, 2023	12	10	755	755
Other Island Generation:		210	MW	Sunday, October 8, 2023	9	8	790	790
ML/LIL Imports:		423	MW	Monday, October 9, 2023	8	9	850	850
Current St. John's Temperature & Windchill:	5 °C	N/A	°C	Tuesday, October 10, 2023	11	10	830	830
7-Day Island Peak Demand Forecast:		1,190	MW	Wednesday, October 11, 2023	10	9	830	830
Supply Notes For October 05, 2023								

Notes:
Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.

- 2. Due to the Island system having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units there may be a requirement for some customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes. With the activation of the Maritime Link frequency controller during the winter of 2018, UFLS events have occurred less frequently.
- 3. As of 0800 Hours.
- 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
- 5. Gross output from all Island sources (including Note 4).
- 6. NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
- 7. Adjusted for curtailable load, market activities and the impact of voltage reduction when applicable.
- 8. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold

Island Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak					
Wed, Oct 04, 2023	Actual Island Peak Demand ⁹	20:00	1,097 MW		
Thu, Oct 05, 2023	Forecast Island Peak Demand		1,190 MW		