


Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Monday, April 01, 2024

Section 1 Island Interconnected System - Supply, Demand & Exports Actual 24 Hour System Performance For Friday, March 29, 2024



Island Supply Notes For March 29, 2024 ¹

- A As of 0800 hours, May 21, 2023, Holyrood Unit 2 unavailable due to forced extension to planned outage (170 MW).
- B As of 2059 hours, July 13, 2023, Stephenville Gas Turbine unavailable due to forced outage (50 MW).
- C As of 1400 hours, February 06, 2024, St. Anthony Diesel Plant available at 8.7 MW due to forced derating (9.7 MW).
- D As of 1102 hours, March 06, 2024, Holyrood Unit 1 available at 160 MW (170 MW).
- E As of 0851 hours, March 24, 2024, Hinds Lake Unit unavailable due to planned outage (75 MW).
- F As of 2013 hours, March 27, 2024, Labrador Island Link available at 450 MW due to forced derating (700 MW) - Bipole.
- G At of 1616 hours, March 29, 2024, Holyrood Unit 3 available but not operating (150 MW).

Section 2 Island Interconnected System - Supply, Demand & Outlook

Sat, Mar 30, 2024	Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast ⁸	Adjusted ⁶
Island System Supply: ⁴	1,595 MW	Saturday, March 30, 2024	1,030	938
NLH Island Generation: ^{3,7}	1,235 MW	Sunday, March 31, 2024	1,060	968
NLH Island Power Purchases: ⁵	130 MW	Monday, April 1, 2024	1,210	1,116
NP and CBPP Owned Generation:	230 MW	Tuesday, April 2, 2024	1,230	1,136
LIL Net Imports to Island: ⁹	- MW	Wednesday, April 3, 2024	1,265	1,170
		Thursday, April 4, 2024	1,200	1,106
7-Day Island Peak Demand Forecast:	1,265 MW	Friday, April 5, 2024	1,235	1,141

Island Supply Notes For March 30, 2024

- H At 0645 hours, March 30, 2024, Labrador Island Link available at 450 MW due to forced derating (700 MW) - Monopole.
- I At 0652 hours, March 30, 2024, Labrador Island Link unavailable due to forced outage (700 MW).

Notes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.

2. As of 0800 Hours.

3. Gross continuous unit output.

4. Gross output from all Island sources (including Note 4).

5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).

6. Adjusted for interruptible load and the impact of voltage reduction when applicable.

7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.

8. Does not include ML Exports.

9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3 Island Peak Demand and Exports Information Previous Day Actual Peak and Current Day Forecast Peak

Fri, Mar 29, 2024	Island Peak Demand ¹⁰	11:30	968 MW
	Exports at Peak		381 MW
	LIL Net Imports to Island		1,228 MWh
Sat, Mar 30, 2024	Forecast Island Peak Demand		1,030 MW

Notes: 10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).