
Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Monday, April 22, 2024



7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for

full rated output. This threshold is dependent on the design of each turbine.

8. Does not include ML Exports.

9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3 Island Peak Demand and Exports Information Previous Day Actual Peak and Current Day Forecast Peak			
Sat, Apr 20, 2024	Island Peak Demand ¹⁰	7:05	1,048 MW
	Exports at Peak		250 MW
	LIL Net Imports to Island		482 MWh
un, Apr 21, 2024	Forecast Island Peak Demand		1,100 MW
lotes: 10. Island Demand is supplie (Deer Lake Power, DLP).	d by NLH generation and purchases, LIL Imports plus generation owned a	nd operated by Newfoundland Power ar	nd Corner Brook Pulp & Paper