


Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Thursday, May 02, 2024

Section 1 Island Interconnected System - Supply, Demand & Exports Actual 24 Hour System Performance For Wednesday, May 01, 2024



Island Supply Notes For May 01, 2024

- A As of 0800 hours, May 21, 2023, Holyrood Unit 2 unavailable due to forced extension to planned outage (170 MW).
- B As of 2059 hours, July 13, 2023, Stephenville Gas Turbine unavailable due to forced outage (50 MW).
- C As of 1400 hours, February 06, 2024, St. Anthony Diesel Plant available at 8.7 MW due to forced derating (9.7 MW).
- D As of 1011 hours, April 12, 2024, Holyrood Unit 1 unavailable due to planned outage (170 MW).
- E As of 0836 hours, April 22, 2024, Holyrood Gas Turbine unavailable due to planned outage (123.5 MW).
- F As of 1505 hours, April 28, 2024, Bay d'Espoir Unit 5 unavailable due to planned outage (76.5 MW).
- G As of 1505 hours, April 28, 2024, Bay d'Espoir Unit 6 unavailable due to planned outage (76.5 MW).
- H As of 0647 hours, April 30, 2024, Labrador Island Link unavailable due to planned outage (700 MW).

Section 2 Island Interconnected System - Supply, Demand & Outlook

Thu, May 02, 2024	Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast ⁸	Adjusted ⁶
Island System Supply: ⁴ NLH Island Generation: ^{3,7} NLH Island Power Purchases: ⁵ NP and CBPP Owned Generation: LIL Net Imports to Island: ⁹	1,365 MW 1,025 MW 140 MW 200 MW - MW	Thursday, May 2, 2024	1,055	1,005
		Friday, May 3, 2024	1,030	980
		Saturday, May 4, 2024	1,045	995
		Sunday, May 5, 2024	1,030	980
		Monday, May 6, 2024	1,040	990
		Tuesday, May 7, 2024	1,035	985
		Wednesday, May 8, 2024	1,055	1,005
7-Day Island Peak Demand Forecast:	1,055 MW			

Island Supply Notes For May 02, 2024

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. As of 0800 Hours.
 3. Gross continuous unit output.
 4. Gross output from all Island sources (including Note 4).
 5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
 7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
 8. Does not include ML Exports.
 9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3 Island Peak Demand and Exports Information Previous Day Actual Peak and Current Day Forecast Peak

Wed, May 01, 2024	Island Peak Demand ¹⁰	8:05	1,038 MW
	Exports at Peak		0 MW
	LIL Net Imports to Island		0 MWh
Thu, May 02, 2024	Forecast Island Peak Demand		1,055 MW

- Notes: 10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).