
Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Friday, May 17, 2024

Section 1

Island Interconnected System - Supply, Demand & Exports
Actual 24 Hour System Performance For Thursday, May 16, 2024



Island Supply Notes For May 16, 2024

- As of 0800 hours, May 21, 2023, Holyrood Unit 2 unavailable due to forced extension to planned outage (170 MW).
- As of 2059 hours, July 13, 2023, Stephenville Gas Turbine unavailable due to forced outage (50 MW).
- As of 1400 hours, February 06, 2024, St. Anthony Diesel Plant available at 8.7 MW due to forced derating (9.7 MW).
- As of 1011 hours, April 12, 2024, Holyrood Unit 1 unavailable due to planned outage (170 MW).
- As of 1505 hours, April 28, 2024, Bay d'Espoir Unit 5 unavailable due to planned outage (76.5 MW).
- As of 1505 hours, April 28, 2024, Bay d'Espoir Unit 6 unavailable due to planned outage (76.5 MW).
- G As of 2306 hours, May 06, 2024, Labrador Island Link available at 450 MW due to forced derating (700 MW) Bipole.
- H As of 0807 hours, May 13, 2024, Hardwoods Gas Turbine unavailable due to planned outage (50 MW).
- As of 1656 hours, May 13, 2024, Holyrood Unit 3 available but not operating (150 MW).
- At 0930 hours, May 16, 2024, Bay d'Espoir Unit 2 unavailable due to planned outage (76.5 MW).
- K At 1358 hours, May 16, 2024, Bay d'Espoir Unit 2 available (76.5 MW).

Section 2

Island Interconnected System - Supply, Demand & Outlook

Fri, May 17, 2024	Island System Outlook ²		Seven-Day Forecast	Island System Daily Peak Demand (MW)	
				Forecast ⁸	Adjusted ⁶
Island System Supply: ⁴	1,316	MW	Friday, May 17, 2024	935	885
NLH Island Generation: ^{3,7}	950	MW	Saturday, May 18, 2024	915	865
NLH Island Power Purchases:5	115	MW	Sunday, May 19, 2024	1,015	965
NP and CBPP Owned Generation:	215	MW	Monday, May 20, 2024	1,070	1,020
LIL Net Imports to Island: ⁹	36	MW	Tuesday, May 21, 2024	1,060	1,010
			Wednesday, May 22, 2024	1,000	950
7-Day Island Peak Demand Forecast:	1,070	MW	Thursday, May 23, 2024	935	885

Island Supply Notes For May 17, 2024

otes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.

- 2. As of 0800 Hours.
- 3. Gross continuous unit output.
- 4. Gross output from all Island sources (including Note 4).
- 5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
- 6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
- 7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
- 8. Does not include ML Exports.
- 9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3 Island Peak Demand and Exports Information Previous Day Actual Peak and Current Day Forecast Peak					
Thu, May 16, 2024	Island Peak Demand ¹⁰	8:15	897 MW		
	Exports at Peak		380 MW		
	LIL Net Imports to Island		908 MWh		
Fri, May 17, 2024	Forecast Island Peak Demand		935 MW		

Notes: 10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).