


Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Monday, September 09, 2024

Section 1 Island Interconnected System - Supply, Demand & Exports Actual 24 Hour System Performance For Sunday, September 08, 2024



Island Supply Notes For September 08, 2024 ¹

- A As of 2059 hours, July 13, 2023, Stephenville Gas Turbine unavailable due to forced outage (50 MW).
- B As of 1011 hours, April 12, 2024, Holyrood Unit 1 unavailable due to planned outage (170 MW).
- C As of 0700 hours, May 26, 2024, Holyrood Unit 3 unavailable due to planned outage (150 MW).
- D As of 0800 hours, August 04, 2024, Holyrood Unit 2 unavailable due to planned outage (170 MW).
- E As of 0800 hours, August 11, 2024, Bay d'Espoir Unit 4 unavailable due to planned outage (76.5 MW).
- F As of 1049 hours, August 25, 2024, Cat Arm Unit 1 unavailable due to planned outage (67 MW).
- G As of 1643 hours, September 07, 2024, Labrador Island Link available at 450 MW due to forced derating (700 MW) - Bipole.
- H At 1534 hours, September 08, 2024, Bay d'Espoir Unit 3 available (76.5 MW).

Section 2 Island Interconnected System - Supply, Demand & Outlook

Mon, Sep 09, 2024	Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast ⁸	Adjusted ⁶
Island System Supply: ⁴	1,435 MW	Monday, September 9, 2024	770	720
NLH Island Generation: ^{3,7}	1,010 MW	Tuesday, September 10, 2024	710	660
NLH Island Power Purchases: ⁵	100 MW	Wednesday, September 11, 2024	735	685
NP and CBPP Owned Generation:	170 MW	Thursday, September 12, 2024	750	700
LIL Net Imports to Island: ⁹	155 MW	Friday, September 13, 2024	750	700
		Saturday, September 14, 2024	735	685
7-Day Island Peak Demand Forecast:	775 MW	Sunday, September 15, 2024	775	725

Island Supply Notes For September 09, 2024

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. As of 0800 Hours.
 3. Gross continuous unit output.
 4. Gross output from all Island sources (including Note 4).
 5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
 7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
 8. Does not include ML Exports.
 9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3 Island Peak Demand and Exports Information Previous Day Actual Peak and Current Day Forecast Peak

Sun, Sep 08, 2024	Island Peak Demand ¹⁰	20:00	704 MW
	Exports at Peak		199 MW
	LIL Net Imports to Island		2,121 MWh
Mon, Sep 09, 2024	Forecast Island Peak Demand		770 MW

- Notes: 10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).