
Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Tuesday, September 24, 2024

Section 1 Island Interconnected System - Supply, Demand & Exports Actual 24 Hour System Performance For Monday, September 23, 2024



Island Supply Notes For September 23, 2024

- A As of 2059 hours, July 13, 2023, Stephenville Gas Turbine unavailable due to forced outage (50 MW).
- B As of 1011 hours, April 12, 2024, Holyrood Unit 1 unavailable due to planned outage (170 MW).
- C As of 0700 hours, May 26, 2024, Holyrood Unit 3 unavailable due to planned outage (150 MW).
- As of 0800 hours, August 04, 2024, Holyrood Unit 2 unavailable due to planned outage (170 MW).
- E As of 0800 hours, August 11, 2024, Bay d'Espoir Unit 4 unavailable due to planned outage (76.5 MW).
- F As of 0941 hours, September 15, 2024, Cat Arm Unit 2 unavailable due to planned outage (67 MW).
- As of 0539 hours, September 16, 2024, Labrador Island Link available at 450 MW due to planned derating (700 MW) Monopole.
- H As of 0437 hours, September 21, 2024, Labrador Island Link unavailable due to planned outage (700 MW).

Section 2 Island Interconnected System - Supply, Demand & Outlook

Tue, Sep 24, 2024	Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast ⁸	Adjusted ⁶
Island System Supply:⁴	1,280 MW	Tuesday, September 24, 2024	800	762
NLH Island Generation: ^{3,7}	1,010 MW	Wednesday, September 25, 2024	770	732
NLH Island Power Purchases:5	75 MW	Thursday, September 26, 2024	790	752
NP and CBPP Owned Generation:	195 MW	Friday, September 27, 2024	785	747
LIL Net Imports to Island: ⁹	- MW	Saturday, September 28, 2024	780	742
		Sunday, September 29, 2024	690	652
7-Day Island Peak Demand Forecast:	885 MW	Monday, September 30, 2024	885	847

Island Supply Notes For September 24, 2024

Notes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.

- 2. As of 0800 Hours.
- 3. Gross continuous unit output.
- 4. Gross output from all Island sources (including Note 4).
- 5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
- 6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
- 7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
- 8. Does not include ML Exports.
- 9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3 Island Peak Demand and Exports Information Previous Day Actual Peak and Current Day Forecast Peak					
Mon, Sep 23, 2024	Island Peak Demand ¹⁰	8:10	806 MW		
	Exports at Peak		0 MW		
	LIL Net Imports to Island		0 MWh		
Tue, Sep 24, 2024	Forecast Island Peak Demand		800 MW		

Notes: 10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).