Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Wednesday, September 25, 2024 Section 1 Island Interconnected System - Supply, Demand & Exports Actual 24 Hour System Performance For Tuesday, September 24, 2024 2200 Peak Island System Demand = 797 MW @ 1745 2000 1800 Supply and Demand (MW) 1600 1400 1200 1000 800 600 400 200 23:15 Island Supply Notes For September 24, 2024 As of 2059 hours, July 13, 2023, Stephenville Gas Turbine unavailable due to forced outage (50 MW). Α В As of 1011 hours, April 12, 2024, Holyrood Unit 1 unavailable due to planned outage (170 MW). С As of 0700 hours, May 26, 2024, Holyrood Unit 3 unavailable due to planned outage (150 MW). D As of 0800 hours, August 04, 2024, Holyrood Unit 2 unavailable due to planned outage (170 MW). Ε As of 0800 hours, August 11, 2024, Bay d'Espoir Unit 4 unavailable due to planned outage (76.5 MW). As of 0941 hours, September 15, 2024, Cat Arm Unit 2 unavailable due to planned outage (67 MW). G As of 0539 hours, September 16, 2024, Labrador Island Link available at 450 MW due to planned derating (700 MW) - Monopole. As of 0437 hours, September 21, 2024, Labrador Island Link unavailable due to planned outage (700 MW). Н Section 2 Island Interconnected System - Supply, Demand & Outlook Island System Daily Peak Island System Outlook² Wed, Sep 25, 2024 Demand (MW) **Seven-Day Forecast** Forecast⁸ **Adjusted**⁶ Island System Supply:⁴ Wednesday, September 25, 2024 1,285 MW 805 767 NLH Island Generation:^{3,7} 1,010 MW Thursday, September 26, 2024 770 732 Friday, September 27, 2024 NLH Island Power Purchases:⁵ 785 747 75 MW NP and CBPP Owned Generation: 200 MW Saturday, September 28, 2024 780 742 LIL Net Imports to Island:⁹ Sunday, September 29, 2024 742 MW 780 Monday, September 30, 2024 795 757 7-Day Island Peak Demand Forecast: 805 MW Tuesday, October 1, 2024 780 742 Island Supply Notes For September 25, 2024 Notes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted. 2. As of 0800 Hours.

3. Gross continuous unit output.

4. Gross output from all Island sources (including Note 4).

5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).

A diverse of few interventions leads and the impress of vertices and vertices where explicitly

6. Adjusted for interruptible load and the impact of voltage reduction when applicable.

7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.

8. Does not include ML Exports.

9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Island Peak Demand and Exports Information Previous Day Actual Peak and Current Day Forecast Peak			
ue, Sep 24, 2024	Island Peak Demand ¹⁰	17:45	797 MW
	Exports at Peak		0 MW
	LIL Net Imports to Island		0 MWh
Ved, Sep 25, 2024	Forecast Island Peak Demand		805 MW
lotes: 10. Island Demand is supplied	by NLH generation and purchases, LIL Imports plus generation owned and op	perated by Newfoundland Power and Corner I	Brook Pulp & Paper (Deer Lake