
Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Friday, October 11, 2024

Section 1

Island Interconnected System - Supply, Demand & Exports Actual 24 Hour System Performance For Thursday, October 10, 2024



Island Supply Notes For October 10, 2024

- A As of 1011 hours, April 12, 2024, Holyrood Unit 1 unavailable due to planned outage (170 MW).
- B As of 0800 hours, August 04, 2024, Holyrood Unit 2 unavailable due to planned outage (170 MW).
- As of 0810 hours, October 06, 2024, Bay d'Espoir Unit 1 unavailable due to planned outage (76.5 MW).
- As of 0810 hours, October 06, 2024, Bay d'Espoir Unit 2 unavailable due to planned outage (76.5 MW).
- As of 0946 hours, October 06, 2024, Upper Salmon Unit unavailable due to planned outage (84 MW).
- At 0648 hours, October 10, 2024, Labrador Island Link unavailable due to planned outage (700 MW).
- At 0801 hours, October 10, 2024, St. Anthony Diesel Plant available at 7.7 MW due to forced derating (9.7 MW).
- H At 1908 hours, October 10, 2024, Labrador Island Link available at 450 MW due to forced derating (700 MW) Monopole.

Section 2

Island Interconnected System - Supply, Demand & Outlook

Fri, Oct 11, 2024	Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast ⁸	Adjusted ⁶
Island System Supply: ⁴	1,390 MW	Friday, October 11, 2024	885	835
NLH Island Generation: ^{3,7}	1,115 MW	Saturday, October 12, 2024	850	800
NLH Island Power Purchases:5	80 MW	Sunday, October 13, 2024	880	830
NP and CBPP Owned Generation:	195 MW	Monday, October 14, 2024	900	850
LIL/ML Net Imports to Island:9	- MW	Tuesday, October 15, 2024	845	795
		Wednesday, October 16, 2024	945	895
7-Day Island Peak Demand Forecast:	980 MW	Thursday, October 17, 2024	980	930

Island Supply Notes For October 11, 2024

At 0746 hours, October 11, 2024, Labrador Island Link unavailable due to planned testing (700 MW)

: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.

- 2. As of 0800 Hours.
- 3. Gross continuous unit output.
- 4. Gross output from all Island sources (including Note 4).
- 5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
- 6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
- 7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
- 8. Does not include ML Exports.
- 9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3 Island Peak Demand and Exports Information Previous Day Actual Peak and Current Day Forecast Peak					
Thu, Oct 10, 2024	Island Peak Demand ¹⁰	8:35	817 MW		
	Exports at Peak		0 MW		
	LIL Net Imports to Island		649 MWh		
Fri, Oct 11, 2024	Forecast Island Peak Demand		885 MW		

Notes: 10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).