


Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Monday, March 31, 2025

Section 1 Island Interconnected System - Supply, Demand & Exports Actual 24 Hour System Performance For Sunday, March 30, 2025



Island Supply Notes For March 30, 2025

- 1
- A As of 0952 hours, March 11, 2025, Granite Canal Unit available at 32 MW due to forced derating (40 MW).
 - B As of 0816 hours, March 26, 2025, St. Anthony Diesel Plant available at 8.85 MW due to forced derating (9.7 MW).
 - C At 0800 hours, March 30, 2025, Holyrood Unit 3 unavailable due to planned outage 130 MW (150 MW).
 - D At 1115 hours, March 30, 2025, Holyrood Gas Turbine available (123.5 MW).

Section 2 Island Interconnected System - Supply, Demand & Outlook

Mon, Mar 31, 2025	Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast ⁸	Adjusted ⁶
Island System Supply: ⁴	2,117 MW	Monday, March 31, 2025	1,305	1,200
NLH Island Generation: ^{3,7}	1,535 MW	Tuesday, April 1, 2025	1,190	1,086
NLH Island Power Purchases: ⁵	105 MW	Wednesday, April 2, 2025	1,270	1,165
NP and CBPP Owned Generation:	220 MW	Thursday, April 3, 2025	1,415	1,309
LIL/ML Net Imports to Island: ⁹	257 MW	Friday, April 4, 2025	1,320	1,215
		Saturday, April 5, 2025	1,305	1,200
7-Day Island Peak Demand Forecast:	1,415 MW	Sunday, April 6, 2025	1,320	1,215

Island Supply Notes For March 31, 2025

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. As of 0800 Hours.
 3. Gross continuous unit output.
 4. Gross output from all Island sources (including Note 3).
 5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
 7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
 8. Does not include ML Exports.
 9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3 Island Peak Demand and Exports Information Previous Day Actual Peak and Current Day Forecast Peak

Sun, Mar 30, 2025	Island Peak Demand ¹⁰	7:30	1,171 MW
	Exports at Peak		335 MW
	LIL Net Imports to Island		749 MWh
Mon, Mar 31, 2025	Forecast Island Peak Demand		1,305 MW

- Notes: 10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).