


Newfoundland Labrador Hydro (NLH)
Supply and Demand Status Report Filed Monday, January 05, 2026

Section 1
Island Interconnected System - Supply, Demand & Exports
Actual 24 Hour System Performance For Tuesday, December 30, 2025



Island Supply Notes For December 30, 2025

A As of 0800 hours, March 30, 2025, Holyrood Unit 3 unavailable due to planned outage 130 MW (150 MW).
 B As of 0823 hours, March 31, 2025, Bay d'Espoir Unit 1 unavailable due to planned outage (76.5 MW).
 C As of 1642 hours, December 17, 2025, Holyrood Unit 1 available at 160 MW due to forced derating (170 MW).
 D As of 1425 hours, December 22, 2025, St. Anthony Diesel Plant available at 7.7 MW due to forced derating (9.7 MW).
 E At 1217 hours, December 30, 2025, Cat Arm Unit 1 available (67 MW).

Section 2
Island Interconnected System - Supply, Demand & Outlook

Wed, Dec 31, 2025	Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)	Forecast ⁸	Adjusted ⁶
Island System Supply: ⁴	2,015 MW	Wednesday, December 31, 2025	1,195	1,101	
NLH Island Generation: ^{3,7}	1,455 MW	Thursday, January 1, 2026	1,220	1,126	
NLH Island Power Purchases: ⁵	95 MW	Friday, January 2, 2026	1,190	1,096	
NP and CBPP Owned Generation:	190 MW	Saturday, January 3, 2026	1,320	1,225	
LIL/ML Net Imports to Island: ⁹	275 MW	Sunday, January 4, 2026	1,365	1,269	
7-Day Island Peak Demand Forecast:	1,440 MW	Monday, January 5, 2026	1,440	1,343	
		Tuesday, January 6, 2026	1,405	1,309	

Island Supply Notes For December 31, 2025

Notes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. As of 0800 Hours.
 3. Gross continuous unit output.
 4. Gross output from all Island sources (including Note 3).
 5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
 7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
 8. Does not include ML Exports.
 9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3
Island Peak Demand and Exports Information
Previous Day Actual Peak and Current Day Forecast Peak

Tue, Dec 30, 2025	Island Peak Demand ¹⁰ Exports at Peak LIL Net Imports to Island	16:55	1,191 MW 239 MW 3,535 MWh
Wed, Dec 31, 2025	Forecast Island Peak Demand		1,195 MW

Notes: 10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).