


**Newfoundland Labrador Hydro (NLH)**  
**Supply and Demand Status Report Filed Monday, February 02, 2026**

**Section 1**  
**Island Interconnected System - Supply, Demand & Exports**  
**Actual 24 Hour System Performance For Saturday, January 31, 2026**



**Island Supply Notes For January 31, 2026**

- A As of 0800 hours, March 30, 2025, Holyrood Unit 3 unavailable due to planned outage 130 MW (150 MW).
- B As of 1425 hours, December 22, 2025, St. Anthony Diesel Plant available at 7.7 MW due to forced derating (9.7 MW).
- C As of 1605 hours, January 24, 2025, Holyrood Unit 1 available at 160 MW due to forced derating (170 MW).
- D As of 0655 hours, January 26, 2026, Cat Arm Unit 2 available at 57 MW due to forced derating (67 MW).
- E At 1033 hours, January 31, 2026, Bay d'Espoir Unit 7 available (154.4 MW).
- F At 1544 hours, January 31, 2025, Holyrood Unit 2 available at 70 MW due to forced derating (170 MW).

**Section 2**  
**Island Interconnected System - Supply, Demand & Outlook**

Sun, Feb 01, 2026	Island System Outlook <sup>2</sup>	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast <sup>8</sup>	Adjusted <sup>6</sup>
Island System Supply: <sup>4</sup>	2,017 MW	Sunday, February 1, 2026	1,280	1,185
NLH Island Generation: <sup>3,7</sup>	1,420 MW	Monday, February 2, 2026	1,355	1,259
NLH Island Power Purchases: <sup>5</sup>	115 MW	Tuesday, February 3, 2026	1,345	1,249
NP and CBPP Owned Generation:	225 MW	Wednesday, February 4, 2026	1,375	1,279
LIL/ML Net Imports to Island: <sup>9</sup>	257 MW	Thursday, February 5, 2026	1,380	1,284
7-Day Island Peak Demand Forecast:	1,380 MW	Friday, February 6, 2026	1,320	1,225
		Saturday, February 7, 2026	1,330	1,235

**Island Supply Notes For February 01, 2026**

Notes:

1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
2. As of 0800 Hours.
3. Gross continuous unit output.
4. Gross output from all Island sources (including Note 3).
5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
8. Does not include ML Exports.
9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

**Section 3**  
**Island Peak Demand and Exports Information**  
**Previous Day Actual Peak and Current Day Forecast Peak**

Sat, Jan 31, 2026	Island Peak Demand <sup>10</sup>	8:25	1,318 MW
	Exports at Peak		217 MW
	LIL Net Imports to Island		7,480 MWh

Notes: 10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).

Forecast Island Peak Demand

1,280 MW