


Newfoundland Labrador Hydro (NLH)
Supply and Demand Status Report Filed Wednesday, February 04, 2026

Section 1
Island Interconnected System - Supply, Demand & Exports
Actual 24 Hour System Performance For Tuesday, February 03, 2026



Island Supply Notes For February 03, 2026

¹

- A As of 0800 hours, March 30, 2025, Holyrood Unit 3 unavailable due to planned outage 130 MW (150 MW).
- B As of 1425 hours, December 22, 2025, St. Anthony Diesel Plant available at 7.7 MW due to forced derating (9.7 MW).
- C As of 0655 hours, January 26, 2026, Cat Arm Unit 2 available at 57 MW due to forced derating (67 MW).
- D As of 1544 hours, January 31, 2025, Holyrood Unit 2 available at 70 MW due to forced derating (170 MW).
- E At 1433 hours, February 03, 2025, Holyrood Unit 1 unavailable due to planned outage 160 MW (170 MW).

Section 2
Island Interconnected System - Supply, Demand & Outlook

Wed, Feb 04, 2026	Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast ⁸	Adjusted ⁶
Island System Supply: ⁴	2,016 MW	Wednesday, February 4, 2026	1,420	1,324
NLH Island Generation: ^{3,7}	1,260 MW	Thursday, February 5, 2026	1,305	1,210
NLH Island Power Purchases: ⁵	105 MW	Friday, February 6, 2026	1,275	1,180
NP and CBPP Owned Generation:	220 MW	Saturday, February 7, 2026	1,340	1,245
LIL/ML Net Imports to Island: ⁹	431 MW	Sunday, February 8, 2026	1,335	1,240
7-Day Island Peak Demand Forecast:	1,465 MW	Monday, February 9, 2026	1,420	1,324
		Tuesday, February 10, 2026	1,465	1,368

Island Supply Notes For February 04, 2026

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. As of 0800 Hours.
 3. Gross continuous unit output.
 4. Gross output from all Island sources (including Note 3).
 5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
 7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
 8. Does not include ML Exports.
 9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3
Island Peak Demand and Exports Information
Previous Day Actual Peak and Current Day Forecast Peak

Tue, Feb 03, 2026	Island Peak Demand ¹⁰	17:35	1,298 MW
	Exports at Peak		352 MW
	LIL Net Imports to Island		4,280 MWh
Wed, Feb 04, 2026	Forecast Island Peak Demand		1,420 MW

- Notes:
10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).