


**Newfoundland Labrador Hydro (NLH)
Supply and Demand Status Report Filed Monday, March 30, 2026**

**Section 1
Island Interconnected System - Supply, Demand & Exports
Actual 24 Hour System Performance For Friday, March 27, 2026**



Island Supply Notes For March 27, 2026

- A As of 1326 hours, February 05, 2026, Cat Arm Unit 2 available at 57 MW due to forced derating (67 MW).
- B As of 2234 hours, March 20, 2026, Holyrood Unit 1 available at 166 MW due to forced derating (170 MW).
- C As of 1438 hours, March 21, 2026, Holyrood Unit 3 available but not operating 50 MW (150 MW).
- D As of 1426 hours, March 22, 2026, Paradise River Unit unavailable due to planned outage (8 MW).
- E As of 1525 hours, March 24, 2026, Holyrood Diesels available at 8 MW due to forced derating (10 MW).
- F As of 1251 hours, March 26, 2026, St. Anthony Diesel Plant available at 7.7 MW due to forced derating (9.7 MW).

**Section 2
Island Interconnected System - Supply, Demand & Outlook**

Sat, Mar 28, 2026	Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast ⁸	Adjusted ⁶
Island System Supply: ⁴ 2,089 MW NLH Island Generation: ^{3,7} 1,515 MW NLH Island Power Purchases: ⁵ 115 MW NP and CBPP Owned Generation: 225 MW LIL/ML Net Imports to Island: ⁹ 234 MW 7-Day Island Peak Demand Forecast: 1,510 MW		Saturday, March 28, 2026	1,370	1,274
		Sunday, March 29, 2026	1,420	1,324
		Monday, March 30, 2026	1,510	1,413
		Tuesday, March 31, 2026	1,435	1,338
		Wednesday, April 1, 2026	1,430	1,333
		Thursday, April 2, 2026	1,330	1,235
		Friday, April 3, 2026	1,405	1,309

Island Supply Notes For March 28, 2026

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. As of 0800 Hours.
 3. Gross continuous unit output.
 4. Gross output from all Island sources (including Note 3).
 5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
 7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
 8. Does not include ML Exports.
 9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

**Section 3
Island Peak Demand and Exports Information
Previous Day Actual Peak and Current Day Forecast Peak**

Fri, Mar 27, 2026	Island Peak Demand ¹⁰	20:45	1,224 MW
	Exports at Peak		280 MW
	LIL Net Imports to Island		1,495 MWh
Sat, Mar 28, 2026	Forecast Island Peak Demand		1,370 MW

- Notes:
10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).